



**COMBINATION (WILD-LEG) SERVICE
1 $\frac{1}{3}$ - 120/240 VOLT
4 WIRE**

△	<i>GENERAL NOTES</i>	ELECTRIC SERVICE STANDARD CITY UTILITIES OF SPRINGFIELD MO.			
	<ol style="list-style-type: none"> 1. ALL SERVICE ENTRANCE CONDUCTORS SHALL TERMINATE IN A THREE-PHASE DISCONNECT OR PANEL. THIS DEVICE CAN ACCOMMODATE ALL THREE-PHASE LOAD AS WELL AS 240 VOLT SINGLE PHASE LOADS. 2. A SEPARATE 120/240 VOLT PANEL SHALL SERVICE ALL LIGHTING AND BRANCH CIRCUITS. 3. PERMANENT (METAL OR HARD PLASTIC) LABEL REQUIRED ON ALL "WILD-LEG" DELTA SERVICES. LETTERS SHALL BE NO SMALLER THAN 3/8" HIGH. 	DRAWN BY: G.GUEVARA	PANEL CONNECTION DETAIL COMBINATION (WILD-LEG) 1ϕ/3ϕ - 120/240 VOLT 4-WIRE SERVICE		
REV BY: W.BROOKS	FILE: SO-GN5				
	APPROVED: 08/21/06	REVISED:	SHEET 1 OF 1	STD. NO. SO-GN5	