



MATERIAL LIST

QTY	DESCRIPTION	STOCK NO.	QTY	DESCRIPTION	STOCK NO.
1	GAS TAP TEE SIZE AS CALLED OUT ON THE INDIVIDUAL DESIGN DRAWINGS.				
2	OUTLET PIPING				
3	CAP				
4	TRACER WIRE				

GENERAL NOTES

- 1 MINIMUM DITCH WIDTH WHEN TRENCHING IN ROCK 26"
- 2 WHEN TRENCHING IN SOLID ROCK; A SIDE DITCH SHALL BE CUT PERPENDICULAR TO THE MAIN DITCH AT ALL LOCATIONS WHERE GAS SERVICES OR LATERALS ARE SHOWN OR WHERE DESIGNATED BY THE INSPECTOR OR SUPERVISOR.

**CONSTRUCTION STANDARD
CITY UTILITIES
OF SPRINGFIELD, MISSOURI**

**INSTALLATION OF
MAIN IN SOLID
ROCK BY USE
OF TRENCHER**