



END OF MAIN TO BE DETERMINED BY PROJECT ENGINEER

2" BLOW-OFF & SAMPLE ASSEMBLY

INSTALL PVC RESTRAINTS ON ALL JOINTS PER ENGINEERS INSTRUCTIONS.

2" X 22-1/2" SOLVENT WELD SCHEDULE 80 ELL (TYPICAL)

△	GENERAL NOTES		CONSTRUCTION STANDARD CITY UTILITIES OF SPRINGFIELD, MISSOURI	
	1.	USE 2" SOCKET X SOCKET SOLVENT WELD COUPLING ONLY. PUSH JOINT PIPE BELLS ARE NOT ACCEPTABLE	WATER MAIN INSTALLATION IN CUL-DE-SAC	
2.	DO NOT BEND 2" PIPE IN DITCH AROUND CUL-DE-SAC.			
3.	SEE STANDARD WS-104/107			
4.	SEE STANDARD WS-109			
	LATEST REV. DATE	STANDARD NO.	PAGE:	
	12/04/02	WS-103		