



**MATERIAL LIST**

QTY	DESCRIPTION	STOCK NO.	QTY	DESCRIPTION	STOCK NO.
1.	1 TAPPING SLEEVE				
2.	1 MJ X FLG TAPPING VALVE				
3.	BELL AND SPIGOT END OF WATER MAIN SERVICE TAP OR LATERAL TAP				
4.	SERVICE LATERAL				

**GENERAL NOTES**

- TAPPING SLEEVE SHALL BE 18" MINIMUM DISTANCE TO ANY JOINT OR OTHER TAPPING SLEEVE.

**CONSTRUCTION STANDARD  
CITY UTILITIES  
OF SPRINGFIELD, MISSOURI**

**MINIMUM SEPARATION  
OF FITTINGS FROM WATER  
MAIN TAPPING SLEEVE**