



MATERIAL LIST

QTY	DESCRIPTION	STOCK NO.	QTY	DESCRIPTION	STOCK NO.
1	MAIN SIZE x MJ VALVE	*	11	3 MAIN SIZE RETAINER GLAND	*
2	MAIN SIZE PE x MJ 90° BEND	*	12	1 LID BLOW-OFF	00301801
3	MAIN SIZE PE x 4" MJ REDUCER	*	13	1 4" RETAINER GLAND	00303182
4	AS REQ TRACER WIRE	00211571			
5	1 VALVE BOX, LONG ADJUSTABLE	00310070			
6	1 BASE, VALVE BOX	00310010			
7	1 THRUST BLOCK PER STANDARD WS-400				
8	1 4" FLANGED x PE DI NIPPLE x 48"	00301266			
9	1 18" x 36" METER TILE	00310060			
10	1 4" D.I. COUPLING, FLANGE x MALE CAM AND GROOVE	00305332			

GENERAL NOTES

- 1 PROTECT JOINTS AND BOLTS FROM CONCRETE.
- 2 TRACER WIRE INSIDE VALVE BOX.
- 3 TILE TO BE BLOCKED TO REQUIRED GRADE.
- 4 WOOD BLOCKS MUST BE A MINIMUM 2"x6" x 18".
- 5 DRILL ONE 1/4" DRAIN HOLE.
- 6 REQUIRES WATER SAMPLE ASSEMBLY PER WS-109.

* - VARIES WITH PIPE SIZE

CONSTRUCTION STANDARD
CITY UTILITIES OF
SPRINGFIELD, MISSOURI

6", 8" AND 12"
BLOW OFF

LATEST REV. DATE: 08/14/2007
STANDARD NO.: WS-108
PAGE: