



RECOMMENDED STANDARD CASING SPACER PLACEMENT ON DUCTILE IRON PIPE

MATERIAL LIST

QTY	DESCRIPTION	STOCK NO.	QTY	DESCRIPTION	STOCK NO.
1	STAINLESS STEEL CASING SPACERS				
2	1 BARE STEEL CASING PIPE, AS SPECIFIED BY ENGINEER				
3	1 CARRIER PIPE				
4	2 FROTH PAK	211087			
5	FIELD LOC GASKET				

GENERAL NOTES

- 1 CONSULT CONSTRUCTION DRAWING FOR NUMBER OF CASING SPACERS.
- 2 MAXIMUM SPACING OF 8" CASING SPACERS IS TEN FEET O.C. ON SIZES UP TO 48" DUCTILE IRON, STEEL, ASBESTOS CEMENT, AND C-900 PVC PIPES. FOR 24" AND LARGER PIPE 6' INTERVALS AND/OR 12" WIDE SPACERS SHOULD BE CONSIDERED IF THE SEPARATION BETWEEN CARRIER AND CASING IS GREATER THAN 5".
- 3 FIRST AND LAST CASING SPACERS TO BE NOT MORE THAN TWELVE INCHES FROM EACH END OF CASING.
- 4 CASING SHALL BE SEALED ON BOTH ENDS WITH FROTH PAK.
- 4 NO LESS THAN TWO SPACERS PER SECTION OF PIPE

CONSTRUCTION STANDARD
CITY UTILITIES
OF SPRINGFIELD, MISSOURI

INSTALLATION OF DUCTILE
IRON WATER MAIN
THROUGH STEEL CASING