



POT-HOLE SPAN CHART	
FACILITY SEPARATION WALL-TO-WALL	SPAN BETWEEN POT-HOLES
< 2'	ENGINEER APPROVAL
2'-3'	30'
3'-5'	40'
5'-10'	75'
> 10'	POT-HOLES NOT REQ.



#### GENERAL NOTES

- 1 WHEN PARALLELING, A SEPARATION OF 2', WALL TO WALL, IS THE STANDARD MINIMUM. HOWEVER, CLEARANCES OF LESS MAY BE APPROVED BY THE RESPONSIBLE ENGINEER.

**CONSTRUCTION STANDARD  
CITY UTILITIES  
OF SPRINGFIELD, MISSOURI**

**RECOMMENDED POTHOLING  
OF EXISTING FACILITIES  
WHEN INSTALLING GAS  
CASING BY  
TRENCHLESS METHODS**

LATEST REV. DATE	STANDARD NO.	PAGE:
04/10/2019	GS-178	