

	GENERAL NOTES	CONSTRUCTION STANDARD
1	3/4" GAS LATERAL (TYP).	CITY UTILITIES
2	TYPICAL JOINT TRENCH GAS AND ELECTRIC INSTALLATION. ELECTRIC CONDUIT IS 48" DEEP AND LATERALS ARE 30" DEEP.	OF SPRINGFIELD, MISSOURI
3	2" - 4" PVC ELECTRICAL CONDUIT. (MAY BE MULTIPLE CONDUITS)	TYPICAL JOINT TRENCH
4	INSTALL PLASTIC CAP ON END OF GAS LATERALS. ALL GAS LATERALS TO BE STOPPED 1' BEHIND BACK OF CURB. INSTALL MINIMUM OF 3' STUB ON EACH SIDE OF TEE.	INSTALLATION CU GAS & CU ELECTRIC CROSSINGS AND LATERALS
5	2" GAS — BEGIN DEFLECTION 8 — 1/2' EACH SIDE OF TRANSFORMER 4" GAS — BEGIN DEFLECTION 12' EACH SIDE OF TRANSFORMER. DO NOT INSTALL GAS DIRECTLY UNDER TRANSFORMER	LATEST REV. DATE STANDARD NO. PAGE:

09/22/2022

GS-231