



MATERIAL LIST

QTY	DESCRIPTION	STOCK NO.	QTY	DESCRIPTION	STOCK NO.
1	2" FLANGED ANODELESS RISER (SEE GS-250)		12	2" NON-LUBRICATED FLANGED VALVE	204095
2	2" FLANGED PLUG VALVE (SEE GS-250)		13	1" BYPASS VALVE TAP (SEE GS-514)	
3	2" FLANGED INSULATION KIT (SEE GS-420)	204216	14	2" CUSTOMER PIPING STUBBED OUT 24" BEYOND THE BUILDING WALL AND 12" ABOVE GRADE	
4	2" T-STRAINER WITH 100 MESH SCREEN	205245			
5	2" x 2" FLANGED ITRON B38R REGULATOR WITH 1-3/8" ORIFICE. SEE NOTE 2	211885			
6	2" WELD NECK FLANGE	204196			
7	5 2" BLACK STEEL PIPE	201010			
8	3 2" 90° WELD ELL	205050			
9	1 1/4" GAUGE TAP (SEE GS-510)				
10	2 2" STUB ENDS	204106			
2	2" LAP JOINT FLANGES (SEE GS-500)	204105			
11	1 2M OR 3M FLANGED ROTARY METER				

GENERAL NOTES

- LENGTH MAY VARY TO ADJUST ELEVATION OR RUN OF METER SET.
- REGULATOR SHOWN ABOVE IS ONLY SIZED FOR A MAOP 2.9 PSI DISTRICT. FOR LP DISTRICTS LESS THAN MAOP 2.9 PSI REFER TO GS-308 FOR PROPER ORIFICE SIZE.
- INSTALLATION OF METER SET MAY BE MIRRORED RIGHT TO LEFT. ROTATE THE METER AS REQUIRED.
- INSTALL STRAINER DISCHARGE AWAY FROM THE WALL OF THE BUILDING.

CONSTRUCTION STANDARD
CITY UTILITIES OF
SPRINGFIELD, MISSOURI

2M OR 3M
ROTARY METER SET
LP DISTRICT