


Contract Documents
Exhibit B

City Utilities
Technical Specifications
For Developer Installed
Electric, Natural Gas & Water Work

Revised July 26, 2019


SECTION 00007

SEALS PAGE



Duffy Joe Mooney – Professional Engineer MO #2003015012

Only the specifications pertaining to design of the natural gas and water distribution facilities and associated appurtenances have been prepared under my direct supervision and the seal above applies only to that design. The following Technical Specifications are true, complete, and accurate. This is the official document to be used for City Utilities developer installed natural gas and water work until such time City Utilities certifies a revision.



Thomas Frank Arnall – Professional Engineer MO #E-27611

Only the specifications pertaining to design of the electric facilities and associated appurtenances have been prepared under my direct supervision and the seal above applies only to that design. The following Technical Specifications are true, complete, and accurate. This is the official document to be used for City Utilities developer installed electric work until such time City Utilities certifies a revision.

END OF SECTION

SECTION 00010

INDEX TO TECHNICAL SPECIFICATIONS

00001	TECHNICAL SPECIFICATIONS TITLE PAGE
00007	SEALS PAGE
00010	INDEX TO TECHNICAL SPECIFICATIONS
00600	DOT DRUG TESTING REQUIREMENTS
00620	INSURANCE REQUIREMENTS
00820	GENERAL PROJECT REQUIREMENTS
00890	PERMITS
01110	WORK BY OTHERS
01300	COORDINATION
01310	PROJECT PROGRESS MEETINGS
01320	SCHEDULING OF WORK
01330	SUBMITTALS
01350	ENVIRONMENTAL PROTECTION PROCEDURES
01410	REGULATORY REQUIREMENTS
01420	CONSTRUCTION STANDARDS
01425	REFERENCES
01450	CONTRACTOR'S QUALITY CONTROL
01460	INSPECTIONS
01525	FIELD OFFICES AND SHEDS
01720	FIELD ENGINEERING
01770	CONTRACT CLOSE-OUT/CLEANUP
02220	DEMOLITION AND CLEARING
02315	EXCAVATION AND BACKFILLING
02320	UTILITY CASINGS
02410	TUNNELING
02510	WATER PIPING
02515	DISINFECTION AND TESTING
02550	MECHANICAL - NATURAL GAS PIPING
02580	UNDERGROUND ELECTRIC CONDUIT AND EQUIPMENT
02700	PAVING AND SURFACING
02900	LANDSCAPING
03200	CONCRETE REINFORCEMENT
03300	CONCRETE

ATTACHMENT A REQUIRED FORMS & AFFIDAVITS

ATTACHMENT B OTHER FORMS

END OF SECTION

SECTION 00600

DOT DRUG TESTING REQUIREMENTS

- 1.01 This Contract includes work covered by the drug testing requirement of the Department of Transportation, 49 CFR. Part 199 and Part 40. Contractor shall comply with all aspects of those two parts of the Code of Federal Regulations. City Utilities will have the right to inspect for compliance.
- 1.02 Once every three months, deliver to City Utilities the testing records (non-name specific) as requested for the purpose of monitoring the drug and alcohol training and testing program for compliance with DOT Regulations 49 CFR Parts 199 and 40. Said records shall be delivered within 30 days of the end of each three-month period. Additionally, upon 48 hours' notice, deliver to City Utilities the Anti-Drug and Alcohol Misuse Plan for the purpose of monitoring compliance with DOT Regulations 49 CFR Parts 199 and 40.

END OF SECTION

SECTION 00620

INSURANCE REQUIREMENTS

Without limiting any of the other obligations or liabilities of the Contractor, the Contractor shall secure and maintain at its own cost and expense, throughout the duration of this Contract and until the Work is completed and accepted by City Utilities, insurance of such types and in such amounts as may be necessary to protect it and the interests of City Utilities against all hazards or risks of loss as hereunder specified or which may arise out of the performance of the Contract Documents. The form and limits of such insurance, together with the underwriter thereof in each case, are subject to approval by City Utilities. Regardless of such approval, it shall be the responsibility of the Contractor to maintain adequate insurance coverage at all times during the term of the Contract. Failure of the Contractor to maintain coverage shall not relieve him of any contractual responsibility or obligation or liability under the Contract Documents.

The certificate of insurance, including evidence of the required endorsements hereunder or the policies shall be filed with City Utilities within ten (10) days after the date of the receipt of Notice of Award of the Contract to the Contractor and prior to the start of work. All insurance policies shall provide thirty (30) days written notice to be given by the insurance company in question prior to cancellation of such insurance. Such notices shall be mailed, certified mail, return receipt requested, to:

Risk Manager
 City Utilities of Springfield, Missouri
 301 E. Central Street
 P.O. Box 551
 Springfield, MO 65801-0551

The minimum coverage for the insurance referred to herein shall be in accordance with the requirements established below:

- (A) Workers' Compensation* **Statutory
Employer's Liability
 Bodily Injury by Accident—each accident \$1,000,000
 Bodily Injury by Disease—each employee limit \$1,000,000
 Bodily Injury by Disease—policy limit \$1,000,000

- (B) Commercial General Liability Insurance***, Including Premises, Operations, Products and Completed Operations, Contractual Liability, Broad Form Property Damage, Independent Contractors; Such Coverage Shall Apply to Bodily Injury and Property Damage on an “Occurrence Form Basis” with each Occurrence Limit of..... \$1,000,000
 In the Aggregate \$2,000,000

- (C) Automobile Liability Insurance*** Covering Bodily Injury And Property Damage for Owned, Non-owned and Hired Vehicles with a Combined Single Limit of: \$1,000,000

- (D) Umbrella or Excess Insurance*** (Following Form) \$5,000,000

*** City Utilities shall be added as an Additional Insured on (B), (C), & (D) Insurance.

Contractor shall require any and all subcontractors with whom he enters into a contract to perform Work on this Project, to protect, through insurance, against applicable hazards or risks and shall, upon request of City Utilities, provide evidence of such insurance. Contractor shall be liable for all deductible amounts from such insurance and shall indemnify and hold City Utilities harmless therefrom. These Insurance Requirements are intended to be minimum coverages, and City Utilities does not warrant that coverages or amounts will be sufficient protection for contractors or City Utilities. Contractors will be responsible for any deficiencies thereof.

NOTE:

Acord certificate changes regarding cancellation notifications do not lessen the responsibility of vendors to comply with obligations set forth in these insurance requirements. Specifically, the requirement “All insurance policies shall provide thirty (30) days written notice to be given by the insurance company in question prior to material reduction in coverage or protection of City Utilities or cancellation of such insurance.” must be met wherever permitted by law.

Since the requirement cannot be met using the Acord certificate, the requirement can be met by (1) specifically endorsing CU onto each policy to receive notifications or (2) any other means that complies with CU requirements.

END OF SECTION

SECTION 00820

GENERAL PROJECT REQUIREMENTS

PART I GENERAL

1.01 This contract is subject to the terms of City Utilities of Springfield, Missouri General Conditions, which may be found at <https://www.cityutilities.net/wp-content/uploads/purchasing-generalconditions.pdf>. Hard copies of the General Conditions may be requested from City Utilities' Purchasing Department, 301 E. Central, P.O. Box 551, Springfield, MO 65801-0551.

1.02 Work includes, but is not limited to installation, relocation and/or retirement of natural gas and/or water mains, services, electric conduit and associated appurtenances.

1.03 It is the intent of this Contract for the Contractor to install the electric, natural gas and water facilities to the full extent as shown on the Drawings. It is the Contractor's responsibility to build these same electric, natural gas and water lines to meet or exceed the requirements of the U.S. Department of Transportation, the Missouri Public Service Commission, the Missouri Department of Natural Resources regulations and City Utilities' Contract Documents, Technical Specifications, and Construction Standards, whichever is greater. Contractor shall make any minor changes in required fittings or in routing (horizontal or vertical) within the pipeline easements shown on the Drawings or within public rights-of-way as a result of field conditions at no additional cost to City Utilities. Some underground facilities are shown on the Drawings, but the Drawings may not accurately represent the locations of the underground facilities. There may be other underground facilities that are not shown on the Drawings. Contractor shall not use the Drawings to locate underground facilities. Contractor is responsible for locating all underground facilities in accordance with Section 01720.

1.04 NOTIFICATION AND CUSTOMER RELATIONS

A. Notify all residents affected by work done under this Contract at least 48 hours, but no more than 7 days, prior to starting work in the affected area. Notification shall be of a form and format approved by the Inspector.

B. Execute the work in a customer/neighborhood friendly manner. In addition, notify adjacent utility customers and property owners of proposed location of work equipment parked overnight and of proposed material storage areas and stockpiles of sand, gravel and dirt. Adjust parking and material storage to maximize customer satisfaction and to minimize traffic congestion.

C. Existing mailboxes along the route shall remain in service throughout the duration of construction. If necessary, temporary removal and replacement shall be coordinated with property owners and done so during a time when mail service will not be disrupted.

1.05 DEVELOPER INSTALLED QUALIFIED ELECTRIC, NATURAL GAS AND WATER CONTRACTORS: All City Utilities electric, natural gas and water utility installation shall be performed by City Utilities Developer Installed Qualified Contractors. Prequalified Contractor application forms can be obtained from City Utilities Purchasing Department at (417) 831-8679 or purchasing@cityutilities.net.

PART II MATERIALS AND EQUIPMENT

2.01 Contractor shall provide all natural gas and water materials.

2.02 Contractor shall supply all electrical materials per "Developer Installed Work" on drawing. City Utilities to supply the following products: junction cabinets, plastic transformer pads, secondary service pedestals, stand-off brackets for risers and street light bases.

- 2.03 Contractor shall supply any other work materials and supplies as may be required. This would include, but not be limited to: sand, chat or other granular fill material; paint; paint brushes; tools; concrete and forms; topsoil; fertilizer, mulch and grass seed; fencing materials; erosion control materials; skids; dunnage; and welding rod. When Contractor elects to install piping by means other than open trenching then Contractor shall supply casing pipe.
- 2.04 The Inspector will order materials to be supplied by City Utilities from City Utilities' Storeroom for Contractor as needed for the project. Requests for materials should be submitted to the Inspector at least 24 hours in advance.
- 2.05 Contractor shall pick up requisitioned materials at the City Utilities stores facility designated by the Inspector. All materials for the project shall be picked up at one time. However, on larger projects Inspector may designate several pick-ups as the job progresses. Contractor shall provide adequate transportation and labor to load and receive materials, except that City Utilities will provide a forklift and operator as necessary to load heavier items. Contractor shall provide wood blocking, straps, tarps, etc. required for hauling the materials. Materials may be picked up from 9:00 a.m. to 3:00 p.m. Monday through Friday, except holidays.
- 2.06 Generally, most materials issued shall be new. However, City Utilities reserves the right to issue used material which the Inspector has judged to be suitable for reuse.
- 2.07 All labor, tools, equipment and incidentals necessary to complete the work, as well as any materials not specifically provided by City Utilities, shall be completely covered by the prices in the Bid.
- 2.08 Contractor shall be responsible for the material, and for the replacement of lost, damaged or stolen material. Contractor shall examine all material upon receipt, and by acceptance, certify suitability for use. Make objections to issued materials to the Inspector. Inspector will establish a reasonable allowance for pipe waste on each project.
- 2.09 Pick up items normally packaged in bulk quantities in such bulk quantities. Unused quantities shall be returned to the stores facility by the Contractor in clean, like-new. The Inspector will make appropriate requisitions, transfers and returns for each project.
- 2.10 Provide equipment and personnel to handle products by methods to prevent soiling or damage to products or packaging.

PART III EXECUTION

- 3.01 Store fabricated products in such a way to prevent damage to material or packaging. Arrange storage in a manner to provide easy access for inspection or inventory by either the Contractor or the Inspector.
- 3.02 Do not hinder access to fire hydrants, fire and police alarms, mailboxes, water valves, natural gas valves and manholes.
- 3.03 Contractor is responsible for locating and procuring material storage sites. Do not use private property, including City Utilities property, for storage of materials without express written permission of property owner. Provide Inspector with documentation of permission to store materials. Do not damage public or private property in handling or storage of materials.
- 3.04 Make periodic inspection of stored products to ensure that products are maintained under specific conditions, and free from damage or deterioration.

- 3.05 Keep construction area as clean as possible. Control mud and dust to prevent customer dissatisfaction and complaints. Do not allow mud and dirt to enter Storm Sewer system. Keep trash, containers, packaging materials, etc., picked up on a daily basis.
- 3.06 Coordinate driveway closures with property owners. Give all property owners 48 hours advance notification prior to closing driveways.
- 3.07 At the end of the project, return all City Utilities salvage materials (used or new) to the City Utilities stores facility designated by the Inspector. All returned material shall be broken down into stock item components and be delivered in a clean, reusable condition suitable to the Storekeeper.
- 3.08 Inclusive in the work is close coordination with all appropriate jurisdictional agencies. The Contractor is responsible for determining paving requirements not specifically shown on the Drawings (temporary and permanent), construction standards, boring requirements, erosion and sediment control, traffic control and safety requirements of these agencies. No additional payment will be made for compliance to jurisdictional requirements. Contractor is responsible for coordinating the work as described herein.

END OF SECTION

SECTION 00890

PERMITS

PART I GENERAL

- 1.01 City Utilities will obtain railroad and Corps of Engineers permits. Contractor must obtain all other necessary permits and comply with all codes of construction as required by Sections 01350 and 01410.

END OF SECTION

SECTION 01110

WORK BY OTHERS

PART I GENERAL

- 1.01 City Utilities personnel shall operate all main line natural gas valves and perform all purging of natural gas mains. A 48-hour advance notification is required.
- 1.02 City Utilities personnel shall operate all main line water valves and provide labor and equipment for disinfection, flushing and sampling of all water mains. Such work shall require a 48-hour advance notification.
- 1.03 City Utilities will provide equipment, materials and labor for completion of main size taps on water mains unless otherwise specified in the Contract Documents (4” through 12” tap size). Such work shall require a 48-hour advance notification and will not be scheduled after 3:00 p.m. or outside normal working hours for City Utilities’ crews. Contractor shall dig and prepare excavation with appropriately safe shoring and traffic control as necessary. Contractor shall install tapping sleeve, valve and other fittings and provide hoisting equipment for installation and removal of fittings and equipment. City Utilities personnel shall be responsible for removing and disposing of asbestos containing material directly associated with tapping procedures that City Utilities personnel perform. Any removal and disposal of asbestos containing material not directly associated with a tapping procedure performed by City Utilities personnel shall be the responsibility of the Contractor per City Utilities standards.
- 1.04 City Utilities will provide equipment, materials and labor for tapping natural gas mains unless otherwise specified in the Contract Documents (sizes 2” through 12”, 150 psig maximum pressure). Such work shall require a 48-hour advance notification and will not be scheduled after 3:00 p.m. or outside normal working hours for City Utilities’ crews. Contractor shall dig and prepare excavation with appropriately safe shoring and traffic control as necessary. Contractor shall provide hoisting equipment for installation and removal of fittings and equipment.
- 1.05 City Utilities will provide equipment, materials and labor to perform all welding of steel natural gas pipes unless otherwise specified in the Contract Documents. Such work shall require a 48-hour advance notification and will not be scheduled after 3:00 p.m. or outside normal working hours for City Utilities’ crews. Contractor shall dig and prepare excavation with appropriate safe shoring and traffic control as necessary. City Utilities personnel shall be responsible for removing and disposing of asbestos containing material directly associated with welding and tapping operations that City Utilities personnel perform. Any removal and disposal of asbestos containing material not directly associated with welding and tapping performed by City Utilities personnel shall be the responsibility of the Contractor per City Utilities standards.
- 1.06 City Utilities will perform all work that involves modifying components in service regulators such as orifice changes, etc.
- 1.07 City Utilities personnel shall unlock and assist conduit installation in and around all energized junction enclosures, pad-mounted transformers and secondary pedestals. Such Work shall require a 48-hour advance notification. The Contractor shall not dig within 5’ of energized CU equipment or lines

PART II MATERIALS NOT USED

PART III EXECUTION NOT USED

END OF SECTION

SECTION 01300

COORDINATION

PART I GENERAL - This Section includes coordination of trades and coordination with Owner, other contractors and jurisdictional agencies.

PART II MATERIALS - NOT USED

PART III EXECUTION

3.01 Coordinate the work of all trades under this contract.

3.02 Coordinate with existing operations on-site to access and use construction area during normal working hours.

3.03 Coordinate all activities through the Inspector.

3.04 COORDINATION WITH OTHERS

A. The Contractor, by agreeing to perform work under these Contract Specifications, hereby certifies that he is able to furnish labor that can work in harmony with all other elements of labor employed or to be employed on the work.

B. Other Contracts may be awarded during this Contract Time. Some of these Contracts may involve on-site activity which must be coordinated with this Contract. In addition, City Utilities crews may perform other work involving on-site construction which must be coordinated with this Contract.

3.05 Inclusive in the Work is close coordination with all appropriate jurisdictional agencies. No additional payment will be made for compliance to jurisdictional requirements. Contractor is responsible for coordinating the Work as described herein.

3.06 RESOLUTION OF DISPUTES

A. The Contractor and Inspector shall attempt to resolve all disputes.

B. If resolution is not reached, the Contractor may request additional meetings with the Resident Engineer. If a resolution is not reached, the Contractor may request to meet with City Utilities' management. These meetings will be scheduled through the Resident Engineer.

C. In the event that the Contractor fails to satisfactorily resolve disputes or complete work as called for in the Contract, such unresolved disputes or unfinished work may be held as sufficient ground by City Utilities to refuse to enter into any future contracts with the Contractor.

END OF SECTION

SECTION 01310

PROJECT PROGRESS MEETINGS

PART I GENERAL

- 1.01 A pre-construction meeting shall be scheduled prior to start of construction on the project to discuss any aspect of the prosecution of the work.
- 1.02 City Utilities or Contractor may at any time request a project meeting to discuss any aspect of work.
- 1.03 Contractor's resident superintendent must be present at any and all meetings.

PART II MATERIALS – NOT USED

PART III EXECUTION – NOT USED

END OF SECTION

SECTION 01320

SCHEDULING OF WORK

PART I GENERAL – Contractor shall plan, schedule and coordinate work associated with the project so as to minimize conflict with, and potential damage to, existing and new City Utilities facilities.

PART II MATERIALS - NOT USED

PART III EXECUTION

3.01 Contractor shall not begin construction on City Utilities electric, natural gas or water facilities until allowed to proceed by the Inspector.

3.02 Such work shall not begin until the following are complete:

- A. Rough grading to within one (1) foot of final established grades of streets, right-of-ways and at utility ditch lines in the subdivision or at the project site has been performed.
- B. Sanitary sewers and storm water drainage facilities and/or drainage ways where such facilities are located within street rights-of-way or City Utilities' easements have been constructed.

3.03 Contractor shall provide the Inspector at least 24-hour advanced notice before beginning construction of City Utilities facilities or resuming construction activities on City Utilities facilities when such activities have been suspended for more than seven calendar days.

END OF SECTION

SECTION 01330

SUBMITTALS

PART I GENERAL

1.01 As required by Resident Engineer, submit to City Utilities for approval a list of all materials provided by Contractor to be installed on the Project. A sample submittal is included in Attachment A depicting the minimum information and general form of the material submittal. All natural gas piping and HDPE water piping will require a “Certificate of Quality” from the pipe manufacturer specific to that batch or ‘lot’ of pipe, if pipe is supplied by Contractor. All steel natural gas piping supplied by the Contractor shall require mill test reports to be supplied to City Utilities.

1.02 All material to be supplied by the Contractor that is not currently an approved brand shall require prior approval by City Utilities. The current approved Material Specifications & Acceptable Brands are located online at <https://www.cityutilities.net/business/construction/> or by scanning the QR code. Materials supplied by City Utilities will also conform to these Specifications.



1.03 Contact Resident Engineer about any questions regarding approved materials.

PART II MATERIALS – NOT USED

PART III EXECUTION – NOT USED

END OF SECTION

SECTION 01350

ENVIRONMENTAL PROTECTION PROCEDURES

PART I GENERAL

- 1.01 Conduct all construction activities in conformance with all federal, state and local laws, regulations and ordinances for the protection of the environment.
- 1.02 The work under this Contract may affect the City of Springfield's drinking water supply. Under no circumstances shall the Contractor or any of his subcontractors allow any debris, fuel, chemicals, liquids or other materials to enter this water supply through direct or indirect means. Contain and dispose of all materials by means acceptable to the appropriate jurisdictional agency. Have materials on-site for containment of spills such as hydraulic hose breaks, etc.

PART II MATERIALS

- 2.01 No hazardous or toxic materials will be allowed in any phase of the work.
- 2.02 Drilling mud used shall not be harmful to the environment and shall comply with all applicable regulations.

PART III EXECUTION

- 3.01 When required, the Contractor shall acquire a Land Disturbance Permit and provide a Storm Water Pollution Prevention Plan (SWPPP) outlining the Best Management Practices (i.e. mulch logs, silt fences, etc.) that the Contractor is to carry out for the duration of the project.
- 3.02 Contractor shall comply with all requirements of the jurisdictional agency's Land Disturbance Permit and/or SWPPP, when applicable.
- 3.03 Contractor shall install and maintain Best Management Practices for stormwater sediment and erosion control during construction in accordance with the appropriate jurisdictional agency's construction standards. Best Management Practices shall also be utilized on projects when a SWPPP is not required.
- 3.04 All drilling mud shall be contained and reclaimed. Contractor is responsible for any spilled drilling mud.

END OF SECTION

SECTION 01410

REGULATORY REQUIREMENTS

PART I GENERAL

1.01 Conduct all construction activities in conformance with all applicable Federal, State and local laws, regulations and ordinances, including the Occupational Safety and Health Act of 1970 (OSHA) and applicable regulations of the Missouri Public Service Commission.

1.02 PERSONNEL QUALIFICATIONS

Any Contractor personnel performing a “Covered Task” as defined in the Missouri Public Service Commission Pipeline Safety Regulations, 4 CSR 240-40.030, Section 12(D) shall be appropriately Operator Qualified prior to performing such task. Contractors shall submit their Operator Qualification Plan for approval before any work may be performed. The plan must meet all Federal and Missouri Public Service Commission requirements.

- A. The Operator Qualification plan shall include at a minimum:
 - a. List and description of covered tasks covered by the Operator Qualification Plan.
 - b. List and description of all training and evaluation modules that make up the full qualification for each covered task.
 - c. Listing of job classifications with accompanying covered tasks and qualification modules.
 - d. Description of the program under which employees are qualified and identification of any third-party vendors utilized for training and testing.

- B. Per the Plan, employee information is required to be submitted with the plan. At a minimum this shall include:
 - a. List of employees (including pictures) assigned to the project.
 - b. Operator Qualification testing results for each employee assigned to the project.
 - c. When and where each employee on the project was qualified and by whom.
 - d. The expiration date of each current qualification for each employee assigned to the project.
 - e. List and description of covered tasks for which each individual is qualified.

City Utilities reserves the right to deny any submitted plans and require an amended plan to be resubmitted.

Any Contractor personnel installing HDPE water main must have attended a fusion training course and be qualified by City Utilities prior to performing any fusion work on City Utilities water distribution system. City Utilities offers this training, or, Contractor may submit training and qualification records for their personnel to City Utilities for approval.

PART II MATERIALS – NOT USED

PART III EXECUTION – NOT USED

END OF SECTION

SECTION 01420

CONSTRUCTION STANDARDS

PART I GENERAL

City Utilities' Construction Standards and other instructions specified in the Drawings shall be followed for all work on the project. City Utilities will provide hard copies of the current construction standards to the Contractor with the contract documents. Construction Standards may also be viewed and printed at <https://www.cityutilities.net/business/construction/> or by scanning the QR code to the right. City Utilities may make substitutions of equivalent materials or assemblies for those shown in the Construction Standards at no additional cost.



PART II MATERIALS - NOT USED

PART III EXECUTION - NOT USED

END OF SECTION

SECTION 01425

REFERENCES

PART I GENERAL

1.01 REFERENCES AND ABBREVIATIONS

The latest edition of the following specifications covers certain materials and methods to be utilized by the Contractor. Abbreviations as used in the Contract Documents mean the following:

- A. AWWA: American Water Works Association
- B. AGA: American Gas Association
- C. AASHTO: American Association of State Highway & Transportation Officials
- D. API: American Petroleum Institute
- E. ASA: American Standards Association
- F. DOT: United States Department of Transportation
- G. AWS: American Welding Society
- H. AREA: American Railway Engineering Association
- I. ACI: American Concrete Institute
- J. OSHA: Occupational Safety and Health Administration
- K. ASTM: American Society for Testing and Materials
- L. ANSI: American National Standards Institute
- M. IEEE: The Institute for Electrical and Electronics Engineers
- N. NACE: National Association Corrosion Engineers
- O. MANGO: Missouri Association of Natural Gas Operators
- P. NESC: National Electric Safety Code
- Q. PPI: Plastic Pipe Institute
- R. DIPRA: Ductile Iron Pipe Research Association
- S. UNIBELL: PVC Pipe Association

1.02 REFERENCES AND DATES

All standard references apply to the most current versions of these standards except where noted.

END OF SECTION

SECTION 01450

CONTRACTOR'S QUALITY CONTROL

PART I GENERAL

1.01 The Contractor's Resident Superintendent, to the extent qualified, may be used for quality control, supplemented as necessary by additional personnel for surveillance, special technicians or testing facilities to provide capability for the controls required by the Specifications.

PART II MATERIALS - NOT USED

PART III EXECUTION

3.01 Provide for inspection of all work to ensure that materials and supplies are placed and installed in accordance with the Drawings and Specifications. Do not build upon or conceal any feature of work containing uncorrected defects.

END OF SECTION

SECTION 01460

INSPECTIONS

PART I GENERAL

- 1.01 All work is subject to inspection, examination or test, at any time by the Resident Engineer.
- 1.02 The Inspector shall be the designated representative of the Resident Engineer.
- 1.03 The Resident Engineer and Inspector have the right and authority to determine whether the work is being done in accordance with the requirements of the Contract Documents, Drawings and Specifications.

PART II MATERIALS - NOT USED

PART III EXECUTION - NOT USED

END OF SECTION

SECTION 01525

FIELD OFFICES AND SHEDS

PART I GENERAL

1.01 The Contractor is responsible for supplying all of the facilities needed for the successful completion of the job. Maintain all working, storage and parking areas in a neat and orderly manner.

1.02 Obtain and maintain all utility services needed during construction.

1.03 FIELD OFFICES AND SUPERVISION

No field offices will be required unless otherwise specified in the Contract Documents. Provide Inspector with telephone numbers at which Contractor and his Resident Superintendent may be contacted at any time. Designate a minimum of two people as after hour contacts.

PART II MATERIALS AND EQUIPMENT

2.01 Furnish storage space, sanitary facilities, trash disposal and utilities.

2.02 The Contractor will be responsible for access to and from the site without causing damage to any adjacent facilities or surrounding land.

2.03 Provide gate locks to interlock with City Utilities' locks, if applicable. If locks are inappropriately secured prohibiting City Utilities access, they will be forcibly removed.

PART III EXECUTION

3.01 Workers' vehicles are to be parked legally in an area designated by the Contractor.

3.02 Upon completion of the project, remove all traces of temporary facilities. Fill all disturbed grass areas, grade and seed in conformance with Section 02900.

3.03 Maintain the continuity of security systems.

3.04 Upon completion of project, remove all traces of temporary utilities unless instructed otherwise by the Inspector.

END OF SECTION

SECTION 01720

FIELD ENGINEERING

PART I GENERAL

1.01 This section includes requirements for surveying and job layout.

PART II MATERIALS - NOT USED

PART III EXECUTION

3.01 The Contractor is solely responsible for locating all existing underground installations including, without limitation, service connections, in advance of excavating or trenching, by contacting the owners thereof, prospecting, and the use of the Missouri One-Call System and other appropriate locating services. The Contractor shall use its own information and shall not use the Drawings to locate underground facilities, since they may not accurately represent the locations of underground facilities or even the existence of all underground facilities. Contractor shall use all reasonable means necessary to avoid damage to underground facilities including, without limitation, hand-digging.

3.02 Damages to existing City Utilities natural gas or water mains should be reported to the Inspector, 911, and City Utilities central dispatching (417-863-9000). City Utilities will repair all natural gas and water lines broken by tear-out, poor construction, blasting or any other reason due to the construction of these facilities. City Utilities crews will not perform service or meter box relocation work for the Contractor.

3.03 Contractor may elect to temporarily disconnect natural gas or water service lines during the course of the project to facilitate the installation of new mains. Notification shall be given to all customers affected as described in Sections 2515 and 2550. Customers shall be reinstated the same day to minimize disruptions. Some critical customers who may require water for life support, dialysis, etc. may not be able to be disconnected. If Contractor elects to temporarily disconnect the natural gas or water service lines, the fittings necessary to perform that work shall be supplied by the Contractor and approved by the Resident Engineer.

3.04 When blasting is to be performed, Contractor shall notify City Utilities 24 hours in advance so that the Inspector may be present to inspect natural gas and water facilities and arrange for a natural gas and water leak survey prior to blasting.

3.05 INSTRUCTIONS FOR UTILITY STAKING

A. GENERAL

1. City Utilities will provide construction surveying and staking for contracted work directly issued by City Utilities. All surveying and staking shall be performed under the direct supervision of a Professional Land Surveyor. The Surveyor shall set all property corners and stake the limits of any easements where utilities are to be installed. The Surveyor shall layout the construction site prior to the start of work and provide staking for all utility installations. The work shall consist of physically marking and placing stakes necessary for the Contractor to properly install utilities in accordance with the Drawings. After initial construction staking has been completed by City Utilities or its agents, it shall be the responsibility of the Contractor to protect the integrity of the construction stakes. If the construction staking is disturbed or destroyed during construction, the Contractor shall be responsible for any fees incurred by City Utilities for re-staking the remaining work to be completed.

2. For work not directly issued by City Utilities, construction surveying and staking shall be performed as described in the following paragraphs.

B. OFFSETS – DEPTH

1. Stake all utilities as shown on the project drawings with offset staking at 50' intervals. Offset stakes shall be set at nearest R/W or easement line to main but no less than 6 feet off centerline and perpendicular to line at points where the line changes direction. Centerline shall be staked at 50' intervals to correspond with offset stakes. Stakes shall also be placed and appropriately marked at all valves, fire hydrants, tees, taps, meter pit locations, property corners on main sides, lateral/street crossing locations, easement lines and as needed to insure inter-visibility along long runs of main or rough terrains.
2. All cuts shown on stakes are to be to bottom of trench from existing grade at base of offset stake. Necessary cuts shall be calculated based on required cover over natural gas and water mains when site is finished grade. Cover is 3'-0" for electric conduit. On joint trench installations, the required cover for water mains shall be used to determine the necessary cut.

C. CENTERLINE STAKING

1. Water main stakes shall be marked "Centerline Water" on one side and tie with blue flagging.
2. Natural gas main stakes shall be marked "Centerline Gas" on one side and tie with yellow flagging.
3. Electric conduit stakes shall be marked "Centerline Electric" on one side and tie with red flagging.

D. OFFSET STAKING

Offset stakes shall have the offset distance in a circle and the word Water, Gas, or Electric marked on the front side with the cut. Backside of stake is to show the station (if applicable). All cuts will be figured from the ground elevation at the base of the offset stake unless otherwise directed by City Utilities. Tie the flagging colors as per Centerline Staking.

E. LATERALS

Laterals shall be staked at the tee and at the end point of the lateral. Offset stakes shall be set at both ends of the lateral. Natural gas lateral end points will be staked one foot (1') off of the right of way line on the opposite side of the street from the main. Water lateral end points will be staked at the right of way line on the opposite side of the street from the main. The stakes will be marked "Gas Lateral" or "Water Lateral" and tied with respective flagging color. Taps for laterals will be staked on the centerline of the main and marked "Gas Tap" or "Water Tap" and tied with respective flagging color. Offsets will be required on the tap.

F. FIRE HYDRANTS

Fire hydrants are to be staked 6 inches off the right-of-way line unless otherwise dimensioned on drawing. The backside of the stake shall be marked "Fire Hydrant." The front side of the stake will have a cut to the bottom of the trench, and a cut or a fill to the finish grade at that point. This cut or fill will coincide with the bury line on a fire hydrant.

Two offset stakes will also be set on property line/right-of-way, 10 foot either side of fire hydrant stake.

G. ELECTRICAL JUNCTION ENCLOSURES, TRANSFORMERS AND SECONDARY PEDESTALS

Unless otherwise noted, stake electrical junction enclosures, transformers, secondary pedestals and streetlights as shown on the applicable underground distribution standard drawing.

H. CUT SHEETS

Cut Sheets shall be kept on all construction staking and copies must be furnished to the City Utilities' Inspector upon request.

I. CONSTRUCTION STANDARDS

1. See Construction Standards for additional utility staking information.
2. Where natural gas and water mains and electric conduit are placed such that finished grade elevation will be higher than the paralleling centerline of street elevation, the utilities shall be installed below the street centerline elevation at the depths specified in the Construction Standards unless otherwise noted.

END OF SECTION

SECTION 01770

CONTRACT CLOSEOUT

PART I GENERAL

- 1.01 Prior to City Utilities making final payments a continuous signal must be verified on the tracer wire.
- 1.02 Within 14 days after Substantial Completion of construction, City Utilities shall notify the Contractor in writing (i.e. punch list) of any defects or defaults in performance which may have been discovered upon final inspection. The Contractor shall remedy promptly all such defects or defaults before the Construction Project shall be accepted by City Utilities.
- 1.03 In the event the Contractor fails to remedy such defects or defaults within 30 days after notification, City Utilities may elect to correct these defects or defaults and deduct the cost of such corrections from any reimbursements due the Contractor or may bill the Contractor for such corrections. In addition, the Contractor shall be removed from the list of City Utilities approved Contractors for a period of not less than one year from date of completion of project on which deficiencies occurred.

PART II MATERIALS - NOT USED

PART III EXECUTION – NOT USED

- 3.01 Completely remove all traces of equipment, excess materials and debris from the site after all punchlist items have been completed, inspected and approved by Inspector.
- 3.02 Clean-up site to Inspector's satisfaction and leave site as good as or better than original conditions.

END OF SECTION

SECTION 02220

DEMOLITION AND CLEARING

PART I GENERAL

1.01 DESCRIPTION: Work includes, but is not limited to:

- A. Removal of designated items.
- B. Protection of items not designated to be removed.
- C. URBAN FOREST MANAGEMENT POLICY - In an effort to responsibly manage the urban forest, guide all work performed under this Contract to reduce damage to any trees. Perform all work in accordance with the guidelines in the booklet "Trenching and Tunneling Near Trees - A Field Pocket Guide for Qualified Utility Workers." Copies of this booklet are available for inspection at City Utilities Forester located at 828 N. Prince Lane, Springfield, MO. Copies are also available from the National Arbor Day Foundation, 100 Arbor Avenue, Nebraska City, NE 68410.

PART II MATERIALS - NOT USED

PART III EXECUTION

3.01 CONSTRUCTION LIMITS

Inspector will establish construction limits and designate items to be removed and items to remain.

3.02 REMOVAL OF ITEMS

- A. Completely clear, grub and remove tree stumps, brush, hedge and other items within the construction limits not designated to remain.
- B. Existing structures, including, but not limited to, pavement, curbs, sidewalks or other similar objects where portions of these objects are to be left in place, shall be removed to an existing joint or a new joint sawed to a minimum depth of one inch with a true line and vertical face.
- C. Completely remove and dispose of all debris. All concrete, masonry, drainage pipes, reinforcement steel, structural steel, castings, timbers, or other materials not salvageable shall be disposed of by the Contractor at his own expense. Contractor shall provide disposal location for all materials and obtain written approval from property owners for material deposited on private property. Submit written approval of the property owners to the Inspector.

3.03 PROTECTION OF REMAINING ITEMS

- A. The Inspector may designate existing above-ground structures, trees, shrubs and plants that are to remain. Contractor shall preserve without damage these items throughout the construction period.
- B. Contractor shall make temporary fence closures during construction and restore fences to original condition or better upon completion of the work.
- C. Contractor shall protect and restore ornamental trees and shrubs.

END OF SECTION

SECTION 02315

EXCAVATION AND BACKFILLING FOR PIPING

PART I GENERAL

1.01 DESCRIPTION: Work includes, but is not limited to the following as they apply to all natural gas and water mains, services, and casing piping:

- A. Trenching and trench backfilling.
- B. Blasting and rock excavation.
- C. Rough and finish grading.
- D. Furnishing and installing granular fill.

1.02 REGULATORY COMPLIANCE

All excavation and backfill is subject to regulations and permits of appropriate jurisdictional agencies.

PART II MATERIALS AND EQUIPMENT

2.01 PIPE BEDDING MATERIALS

Bed all natural gas mains, water mains, natural gas services, and water services in accordance with the Construction Standards.

2.02 FILL MATERIAL

All fill material shall conform to City Utilities' Construction Standards and is subject to approval of the Inspector.

2.03 BACKFILL IN NON-PAVED AREAS

- A. Other than pipe bedding, backfill with suitable materials excavated from trench and processed as required, or borrowed from locations arranged and paid for by Contractor. Material shall be free from organic matter, refuse, ashes, cinders or other unsuitable materials, and shall not be frozen. Backfill above the bedding may have materials up to a maximum of twelve inches in any dimension. Backfill material shall contain sufficient fines to provide a dense mass capable of being compacted.
- B. Casing installed by open trenching shall be backfilled with materials no greater than four inches in any dimension for the first foot of backfill.

2.04 BACKFILL IN PAVED AREAS

- A. Other than pipe bedding as called out in the applicable Construction Standards, backfill trenches in designated area with granular material that meets the appropriate jurisdictional agency's requirements.
- B. Casing piping installed by open trenching of roadways shall be bedded and backfilled full depth with granular material meeting the specifications of the appropriate jurisdictional agency.

- C. Granular material meeting the specifications of the appropriate jurisdictional agency will be required under sidewalks, existing paved areas, proposed paved areas, unpaved “driven-over” areas utilized as drives or parking lots, as necessary on excavations paralleling proposed or existing streets and drives to avoid settlement of curbs or paving.
- D. When flowable fill is required, natural gas or water lines shall be covered with a protective rock shield.

PART III EXECUTION

3.01 TRENCHING

- A. CENTERLINE: Maintain centerline of the trench in a straight line with minimum bends or changes in direction. When trenching in pavement, saw cut the pavement in a straight line on both sides of the future excavations.
- B. LENGTH: Minimize the amount of open trench length at any time on the same street. Fill trenches as soon as practical after pipe is placed in the ditch and placement and bedding is approved by the Inspector. Coordinate closing of driveways with the individual property owners. Provide adequate access to all businesses during their operating hours.
- C. WIDTH: Maintain width of trench ample to permit pipe to be laid and jointed properly and backfill to be placed and compacted as specified in accordance with applicable construction standards.
- E. DEPTH
 - 1. Depth shall be as shown in Construction Standards, unless otherwise indicated on the Drawings. Measurements shall be made from the low side of the trench. Areas where design depth differs from standard depth will be noted on construction Drawings however minor deviations in grade are to be expected in order to avoid other infrastructure and shall not constitute as additional work or payment due the Contractor.
 - 2. Extra depth ditch may be required to route under existing obstructions. No extra payment will be made for extra depth ditch due to these obstructions.
 - 3. Where natural gas and water mains are placed such that finished grade elevation will be higher than the paralleling centerline of street elevation, the utilities shall be installed below the street centerline elevation at the depths indicated in the constructions standards unless otherwise noted on the construction drawings.
 - 4. Where crossing roadways, piping shall be installed as required by the jurisdictional agency’s permit.
 - 5. NATURAL GAS SERVICES ON PRIVATE PROPERTY: Provide a minimum of 18 inches from the top of the pipe to existing grade unless service is inserted in existing steel service line. Maintain 12 inches minimum cover over inserted steel lines verified as described in natural gas piping section.

E. ADJACENT STRUCTURES, WATER, SEWER, NATURAL GAS LINE AND TELEPHONE CABLE CROSSINGS

1. Follow such method of course as may be approved by the Inspector in passing all underground structures.
2. Exercise extreme care in crossing or paralleling water, sewer, natural gas lines and telephone cables. Cross or parallel all structures at Contractor's sole risk and responsibility. Should any damage occur to such lines, Contractor is fully liable and will pay full cost of repairing same.
3. Make all arrangements and pay for relocation and bracing where poles or anchors are affected by the trenching operation.

F. FOUNDATION FOR PIPE

1. Grade the trench bottom as required to achieve uniform and continuous bearing and support for the pipe on solid and undisturbed earth free from rocks and other obstructions that could cause point loads throughout the length of pipe. Finish subgrade to a straight line between pipe joints.
2. Place, grade and compact to a uniform depth a minimum of six inches of specified bedding material in the ditch bottom prior to placing any pipe in the ditch.
3. Where trench excavation is inadvertently carried below specified grade, backfill with approved trench excavated material in 6-inch lifts compacted to provide a firm and unyielding subgrade.
4. Where the bottom of trench at subgrade is found to be unstable or include ashes, cinders, refuse or other organic material, excavate and remove such unsuitable material and fill according to Item 3, above.

G. TRENCH BRACING AND SHORING: Support all trenches in accordance with all pertinent and applicable codes, rules and regulations.

H. Protect the public from any excavations left open during times when Contractor is not working.

3.02 SPOIL AREAS

- A. Store no spoil off the rights-of-way or easements unless prior written permission has been obtained from the property owner and a copy of said agreement provided to the Inspector.
- B. Locate and maintain off-site spoil areas for excess excavated materials. Restore these areas to satisfactory condition before final payment is approved. Provide a certificate of acceptance from the owner of the spoil area to the Inspector.

3.03 PIPE BEDDING

Pipe bedding shall conform to all applicable Construction Standards.

3.04 BACKFILL AND COMPACTION

- A. Do not backfill trench until work is inspected and approval to proceed with backfill has been given by the Inspector. Complete backfilling promptly after approval to proceed.

- B. Place material in six-inch lifts and compact as necessary to avoid settlement of ditch line. Fill any settled areas for a period of one year after date of acceptance by City Utilities. Restore surface as needed.

3.05

ROCK EXCAVATION

- A. All blasting is performed at the Contractor's sole risk. The Contractor is solely responsible for any and all damages caused by blasting to any adjacent structure or any other underground facilities. If damage does occur to any above or below ground facilities, including other City Utilities facilities, the Contractor is fully liable.
- B. All excavation is considered unclassified. Presence of rock shall not relieve Contractor of depth requirements given in paragraph 3.01. There shall be no change in the Contract Price or Time due to rock, regardless of type or hardness unless provided for in the Bid Documents.
- C. In high hazard areas, remove rock by jackhammering as necessary. Make determination of whether or not rock can be blasted, but Contractor shall be fully liable for any damages.
- D. Perform all blasting in accordance with the City of Springfield's General Ordinance #4714, even for areas outside the jurisdiction of the City of Springfield. Only persons holding blasting licenses as issued by the Springfield Fire Department may perform blasting. Contractor must present areas desired to be blasted to Resident Engineer for prior approval. Upon approval contractor must obtain any necessary blasting permits and submit a copy to the Resident Engineer.

3.06

OPEN CUTTING ROADWAYS

Open cut roadways only as approved by the governing authority. If approval to open cut is not received, crossing must be installed using approved trenchless methods.

3.07

TRAFFIC CONTROL

The Contractor shall prepare a Traffic Control Plan in accordance with the latest edition of the Manual on Uniform Traffic Control Devices and submit it for review and approval to the jurisdictional agency.

END OF SECTION

SECTION 02320

UTILITY CASINGS

PART I GENERAL

1.01 SUMMARY

- A. This section applies to casing pipe installed by tunneling or trenching.
- B. Casings for natural gas and water lines shall be installed per applicable Construction Standards.

1.02 REFERENCES

- A. APPLICABLE STANDARDS
 - 1. AMERICAN PETROLEUM INSTITUTE (API)
 - a. API 1104 – Standard for Welding Pipelines and Related Facilities
 - b. API RP 1102 – Standard for Steel Casings
 - 2. AMERICAN SOCIETY FOR TESTING AND MATERIALS (ASTM)
 - a. A36 – Structural steel
 - b. A570 – Hot-rolled carbon steel sheet and strip, structural quality
 - c. D2513 - Standard Specification for Polyethylene (PE) Gas Pressure Pipe, Tubing, and Fittings
 - 3. AMERICAN WATER WORKS ASSOCIATION (AWWA)
 - a. C206 – Field welding of steel water pipe
 - 4. STEEL STRUCTURES PAINTING COUNCIL (SSPC)
 - a. SP-3 – Power tool cleaning

1.03 SUBMITTALS

If Contractor is supplying materials, submit shop drawings for proposed casing spacers and other items specified by Resident Engineer for approval prior to shipment.

PART II PRODUCTS

2.01 MATERIALS

All materials shall conform to current City Utilities Specifications unless otherwise specified in the Contract Documents. HDPE 4710 DR 11-21 pipe that meets ASTM D2513 is permissible for casing. Natural gas casing shall be black with yellow stripes. Water casing shall be black with blue stripes.

PART III. EXECUTION

3.01 INSTALLATION

- A. All work shall, as a minimum, meet the requirements of API RP1102, the highway, railroad or utility having jurisdiction and shall be subject to their inspection and approval.
- B. Casing pipes installed by tunneling shall conform to the following requirements and Section 02410:
 - 1. Casings rejected due to misalignment or other failures to conform to specifications shall be abandoned in place. The ends of the abandoned casing shall be capped or plugged to provide a tight seal. Casing pipe shall not be recovered for reuse.
 - 2. Casing spacers are not required when installing polyethylene gas or water pipe in a plastic casing unless called for on the Drawings.
- C. Casing pipes installed by open cut shall conform to the following requirements and Section 02315:
 - 1. Bottom of casing may be installed on graded, compacted earth or gravel bedding.
- D. JOINTS
 - 1. All joints along pipe casings shall be joined to conform with the requirements of Sections 02510 and 02550. Contractor shall be responsible for welding steel casing joints. Contractor personnel will not be required to be qualified for joining casing piping.

3.02

GROUTING

- A. Where voids are present the casing pipe shall be grouted per the appropriate jurisdictional requirements.

END OF SECTION

SECTION 02410

TUNNELING

PART I GENERAL

1.01 DESCRIPTION

Includes augering, boring, driving, drilling, moling or other methods approved by Resident Engineer.

1.02 INSTALLATION

- A. Any natural gas pipe installed by tunneling shall either be encased in a steel casing or sleeved in polyethylene gas pipe according to Construction Standards, except as noted in Item B.
- B. Only steel gas pipe with polymer concrete coating over fusion bonded epoxy coating with 'Powercrete' coated joints may be installed uncased as described in the Construction Standards. Manufacturer's cure times on field applied coatings shall be strictly adhered to.
- C. All water pipe intended to be cased shall be noted on the Drawings and shall be installed according to the Construction Standards.
- D. Optional Casing Installations: In locations where tunneling is not required by the Contract Documents, Contractor may elect to tunnel natural gas or water lines, to avoid surface restoration, but only with Resident Engineer's approval. No extra payment will be made for such tunneling and Contractor shall supply or reimburse City Utilities for supplying additional casing materials.

PART II MATERIALS AND EQUIPMENT

2.01 DRILLING FLUIDS: All drilling fluids must be environmentally acceptable and shall be completely contained throughout the drilling process.

PART III EXECUTION

3.01 DIAMETER OF TUNNEL EXCAVATIONS

- D. Perform all directional drilling in accordance with ASTM F1962 and PPI standards.
- E. Maintain diameter of tunnel excavations large enough to allow insertion of the pipe without causing damage to the pipe. Diameter of tunnel excavation shall minimize the amount of annular space between the excavation and the piping.
- F. Maintain diameter of tunnel excavation no more than 2 inches greater than the size of the pipe except 1 ¼" and smaller pipe may be inserted in a 4" tunnel excavation or otherwise approved by Resident Engineer.

3.02 GENERAL TUNNELING SPECIFICATIONS

- A. Tunnel depth shall be at standard depth to the top of casing pipe unless more cover is required by governing jurisdictional agencies, unless otherwise noted on the Drawings.

- B. Establish initial angle of tunnel excavation to maintain design depth throughout the tunnel excavation.
- C. In the event of unforeseen deflections encountered during the tunnel excavation, a vertical upward deflection of up to six inches, vertical downward deflection of up to 18 inches, and lateral deflections up to 18 inches are allowed, provided there is no conflict with existing or proposed facilities. Deflections greater than this are unacceptable and will require re-boring or trenching to the appropriate depth.
- D. During directional drilling, the boring head shall be located utilizing underground locating equipment capable of pinpointing the drill head. This shall be done at least once for every ten feet of drilling length in both the horizontal and vertical directions and provided to Inspector in writing.
- E. Contractor shall ensure sanitary sewer main and lateral crossings are not damaged by exposing them during the tunneling process or by video camera inspection after tunneling is complete. Contractor shall complete City Utilities' Cross Bore Verification Form in Attachment B and submit to the Inspector prior to final payment. Contractor shall also take precautionary measures to avoid damaging all other foreign line crossings (stormwater, telephone, fiber optic, etc.). Contractor shall be responsible for the repair of any damage made to existing facilities. The use of "Fish Tape" for identifying depths of existing sewer mains and/or laterals shall not be an acceptable method for confirmation of depth and/or damage to existing utilities.
- F. Piping installed in tunnel excavation shall be pulled back in one continuous section, as one continuous operation unless otherwise directed by Resident Engineer.
- G. Contractor shall utilize a swivel or other means to minimize rotation of the pipe during pullback.
- H. Contractor shall provide adequate support rollers for the pipe during pullback. Rollers and cradles shall be of a type to prevent damage to the pipe and coating and of sufficient number to prevent overstressing of the pipe due to sag bends during pullback.
- I. In the event the Contractor must abandon the tunnel excavation before completion of the full excavation, the Contractor shall seal the hole per the appropriate jurisdictional agency's guidelines. The Contractor shall then complete a new tunnel excavation at no extra cost to City Utilities.
- J. Observe the bend radius of the piping being installed per the applicable Construction Standards and manufacturers recommendations.
- K. Tracer wire shall be attached to the pull head of the drilling rig and be installed with all natural gas and water piping. Wire used is to be in accordance with the applicable Construction Standards.
- L. When pulling polyethylene gas or water piping the Contractor shall not exceed the allowable tensile load values for safe pullback in accordance with ASTM F1804. Contractor shall use a weak link to prevent over-stressing the pipe during pullback. A mechanical break-away connector or a one-foot section of smaller SDR or diameter plastic pipe placed between the pull head and leading edge of the pipe are acceptable weak links. Below are approximate values for safe pull forces for PE4710 and PE2708 1-12 Hour Pulls.

PE 4710 1-12 Hour Pulls at 73°F*			
Safe Pull Force (lbs)			
Size (in)	SDR 11	SDR 13.5	SDR 17
1	597	-	-
2	1,947	-	-
4	-	6,602	-
6	16,440	13,644	-
8	28,282	23,471	-
12	60,167	49,933	-
16	104,547	86,764	-
18	-	-	87,961

*See Service Temperature Design Factors for temperatures over 80°F

Service Temperature Design Factors for PE 4710	
Service Temperature	Safe Pull Force Multiplier
≤ 80 F	1.00
≤ 90 F	0.90
≤ 100 F	0.80
≤ 110 F	0.71
≤ 120 F	0.63
≤ 130 F	0.57
≤ 140 F	0.50

PE 2708 1-12 Hour Pulls				
Safe Pull Force (lbs.)				
Size (in)	≤ 73°F	≤ 100°F	≤ 120°F	≤ 140°F
0.75	282	257	208	178
1.25	769	700	568	485
2	1,446	1,316	1,068	912
4	5,194	4,725	3,836	3,276
6	11,258	10,241	8,314	7,101
8	19,082	17,357	14,091	12,036

- M. When polyethylene pipe is being installed, an additional 5% pipe length shall be installed at the entry and exit points to allow for relaxation due to temperature. MDPE and HDPE expansion/contraction according to PPI TR-21 handbook are expected to be 1.1 inch per 100 feet per 10 degrees temperature change. Allow piping to achieve the same temperature as the ground to counter act pipe creep prior to making tie-ins at the ends of the piping. The typical relaxation time should be twenty-four hours.

END OF SECTION

SECTION 02510

WATER PIPING

PART I GENERAL

1.01 DESCRIPTION Includes, but is not limited to, installation of water mains, including pipe, valves and fittings. Also includes retirement of mains and service tie-overs as shown on the drawing.

1.02 RELATED WORK DESCRIBED ELSEWHERE

- A. Work by Others, Section 01110.
- B. Field Engineering, Section 01720.
- C. Demolition and Clearing, Section 02220.
- D. Excavation and Backfilling, Section 02315.
- E. Utility Casings, Section 02320.
- F. Tunneling, Section 02410.
- G. Disinfection and Testing, Section 02515.
- H. Paving and Surfacing, Section 02700.
- I. Concrete, Section 03300.

1.03 PRODUCT HANDLING

- A. Use all means necessary to protect the material before, during and after installation.
 - 1. Handle pipe with padded forklifts, wide non-abrasive slings, padded clamps or padded pipe hooks. Pipe must be secured so that it cannot fall while being handled. Conventional chains, chain hooks and non-padded forklifts are expressly forbidden.
 - 2. All coated steel pipe and fittings shall be stored off the ground on wooden pallets or skids.
 - 3. Contractor is responsible for all dents, gouges, coating defects and/or dimensional variations.
- B. In the event of damage, Contractor shall immediately make all repairs and replacements to the approval of the Inspector.

PART II MATERIALS AND EQUIPMENT

2.1 All materials will conform to City Utilities material Specifications unless otherwise indicated on the Drawings or in these Specifications.

2.2 When contaminated soils are encountered unexpectedly, Contractor shall immediately notify Resident Engineer. Engineer may require additional precautions to protect water quality.

2.3 All valves shall be of open right (clockwise) design.

2.4 Ductile iron valves and fittings have a protective coating that shall be protected to minimize damage. Exterior coating defects shall be repaired with petrolatum wax tape.

PART III EXECUTION

3.1 INSTALLATION – GENERAL

Install pipe in strict accordance with the manufacturers' installation instructions and laying schedules. Run true to grade and alignment as shown on the Drawings with fittings and valves at the required locations. Match and make connections to existing fittings at the points of termination of the piping system. Make tie-ins onto existing live water mains under the supervision of the Inspector using approved equipment and materials. Do not operate any valves, blowoffs or similar equipment on the existing water system of City Utilities without prior approval by the Inspector.

3.2 INSTALLATION METHODS

Install pipe by trenching as specified in Technical Specifications, Section 02315, by tunneling as specified in Section 02410, and/or by casing as specified in Section 02320.

3.3 PIPE CLEANING AND PREPARATION

- A. Thoroughly clean and inspect all pipe and fittings for damage before placing in the trench. If damage to pipe is found during inspection, repair or replace the pipe as directed by the Inspector.
- B. Prevent foreign material from entering the pipe while it is being installed. Allow no debris, tools, clothing or other materials in the pipe.
- C. When pipe laying is not in progress for an extended period of time such as nights and weekends, close the open ends of pipe with a water tight plug. If water is in the trench, the seal shall remain in place until the trench is pumped completely dry. Chlorine tablets may be added to the ditch water per AWWA C651 to avoid additional contamination as further described in Section 02515. Do not use hypochlorite intended for use in swimming pools. Do not lay pipe in water or when trench conditions are unsuitable.

3.4 REPAIR OF COATING

In case of damage to the protective coating or lining of ductile iron pipe, repair the pipe in accordance with AWWA C104. Repair of coating damage to epoxy coated surfaces shall be made with petrolatum wax tape.

3.5 PIPE SUPPORT AND EMBEDMENT

Support the barrel of the pipe by the granular leveling course with bell holes excavated for the bell end. Having so supported the pipe, embed it with granular material after joining pipe.

3.6 JOINING PIPE

- A. PUSH-ON JOINTS: In accordance with manufacturers recommendations, lay pipe with bell ends facing in the direction of laying unless directed otherwise by the Inspector. After placing a length of pipe in the trench, clean and lubricate the gasket and gasket groove. Center the spigot end in the bell. Force pipe home giving care to not over-bell the pipe and bring to correct line and grade. Prevent dirt from entering the joint space.

- B. THREADED JOINTS: Pipe dope or thread tape shall be applied to the threads prior to joining. Threaded joints are only to be used on 2” and smaller water lines.
- C. COMPRESSION (PACK OR MECHANICAL) JOINTS: Install and tighten compression fittings per manufacturer’s instructions.
- D. FLANGE JOINTS: Assemble joints above ground and lower into trench, unless otherwise acceptable to the Inspector. Tighten bolts per manufacturer’s instructions.
- E. SOLVENT CEMENT JOINTS: Shall not be used unless indicated on the Drawings.
- F. RESTRAINED JOINTS: Install per manufacturer’s instructions and as detailed on the Drawings.
- G. HDPE CONNECTIONS: Join HDPE pipe per ASTM F2620.

Butt fusions are the preferred method of joining with electro fusion and socket fusion also permissible when joining HDPE to HDPE. Data loggers shall be used when performing butt fusions with a hydraulic machine. City Utilities Inspector will provide the data logger. Hydraulic butt fusion equipment shall be McElroy or pre-approved equal. When equipment other than McElroy is proposed, the Contractor will be required to supply an equivalent data logger or other approved means of capturing fusion data and providing the fusion data to City Utilities Inspector. When joining HDPE to DI or PVC piping a MJ or threaded transition fitting shall be fused to the HDPE to make the change in materials.

Mechanical fittings are only permissible when called for on the Drawing or otherwise called for within the Specifications. A stainless-steel stiffener sized to encompass the entire bearing length of the compression fitting to the HDPE pipe is required when using approved mechanical or compression fittings.

All fusion joints shall be made by competent joiners who shall have been tested and approved in advance by City Utilities, and who have properly maintained this qualification. The test shall include destructive test of joints of each type to be made on the project.

Contractor shall make all fusions in accordance with the current manufacturer’s recommended procedures.

Contractor shall provide an approved machine when butt fusions are to be made. Contractor shall provide all necessary tools, approved by the Inspector, to complete all required fusion. Only tools specifically designed for the joining of polyethylene water pipe shall be used. All tools shall be kept clean.

Contractor shall provide an approved electrofusion machine when electrofusion fittings are to be installed. Contractor shall provide all necessary tools to complete all required fusions to the satisfaction of the Inspector.

The pipe shall be prepared using an approved scraper designed for use with polyethylene piping. Paint-type scrapers will not be allowed unless approved by Resident Engineer.

3.7 PERMISSIBLE DEFLECTION AT JOINTS

Wherever it is necessary to deflect pipe from a straight line, either in the vertical or horizontal plane, to avoid obstructions or plumb valve stems, or where long-radius curves are permitted, deflect in accordance with the manufacturer’s recommendations and Construction Standards for satisfactory joining.

3.8 TIE-IN POINTS AND CROSSINGS

Expose existing casings, mains, storm drains, other utilities, and other obstacles well in advance of trenching and pipe laying to avoid abrupt changes in vertical alignment and the use of unnecessary fittings at tie-in points and crossings.

3.9 CUTTING OF PIPE

Cut pipe for inserting valves, fittings or closure pieces without damage to the pipe or cement lining and leave a smooth end at right angles to the axis of the pipe. Make all cuts in accordance with the manufacturer's instructions. Only cut 16" or larger ductile iron pipe after it has been gauged to determine if the diameter of the pipe is within tolerance at the proposed cut location. HDPE pipe shall be cut with a guillotine style cutter or a chain saw with no lubricant in the bar oiler. Other methods will require approval by Inspector.

3.10 BENDING OF HDPE PIPING:

- A. Install fittings at all locations as specified in the Drawings.
- B. At locations where fittings are not specifically called for, HDPE pipe may be bent to route the line as required; however, bends which would produce excessive stress on the pipe shall not be allowed. The minimum bending radius shall adhere to the appropriate water Standard. Bends of a lesser radius shall not be permitted, and an appropriate fitting (elbow) shall be installed as necessary.

3.11 SQUEEZE-OFF OF HDPE PIPING:

- A. Where available, City Utilities personnel shall utilize valves to control the flow of water in HDPE pipes. However, squeeze-off may be utilized where necessary to control the flow of water.
- B. Contractor shall squeeze-off pipe using a properly designed tool and shall not damage the pipe. The tools shall be equipped with appropriate gap stops. The tools shall be squared and centered on the pipe and shall be located at least three pipe diameters away from the nearest fitting or fusion joint. All squeeze-off shall be performed with the Inspector present.
- C. The same location of pipe shall not be squeezed-off more than once. All squeeze-off locations shall be marked on the pipe with electrical tape.
- D. After squeeze-off, pipe shall be re-rounded. All squeeze-off operations shall conform to manufacturer's recommendations.

3.12 VALVE AND FITTING INSTALLATION

A. VALVES AND FITTINGS

Set and join valves, fittings, plugs and caps to pipe in accordance with the manufacturer's recommendation. Valves shall be installed so operating nut is plumb so valve key will easily operate the valve within the box. Valves shall be installed so that the operating nut is no more than eight feet below finished grade. If the valve is more than eight feet below finished grade the Contractor shall install a valve extension shaft.

B. VALVE BOXES

Install the valve box so as not to transfer surface loads directly onto the valve. Center and plumb valve box over the operating nut of the valve, with the box cover flush with the surface of the finished pavement or such other level as may be directed by the Inspector.

C. ANCHORAGE FOR VALVES AND FITTINGS

All fittings shall have suitable thrust protection as indicated on the Drawing or in the Construction Standards.

3.13 SERVICE LINES AND METER SETS

A. Water services: The minimum size of service lines shall be 1” piping from main to meter set unless otherwise called for on the Drawings. Meter sets shall be constructed per the Drawings and applicable standards. Services and meters shall be installed according to the applicable Construction Standards and Drawings. New piping shall be installed from the outlet of the meter setting to the customer’s property line and tied over to the existing customer piping if it exists. No heat bending of piping material shall be allowed.

B. Fire Services: The minimum size of fire service lines shall be 2” piping from the main to the customer’s property line or easement line. The customer’s piping shall be considered the property line or easement line unless a fire service valve is installed, in that case, the customer’s ownership will be the point immediately downstream of the valve.

3.14 LOCATOR WIRE & WARNING TAPE

A. Install tracer wire per Construction Standards.

B. Warning tape shall be installed with all water mains and services that are installed by trenching per applicable Construction Standards.

3.15 WORK EQUIPMENT AND TOOLS

Furnish work equipment and tools necessary for the installation and connection of mains.

3.16 MAIN TAPS

City Utilities will furnish equipment and labor for tapping of water mains (2”-12” tap sizes). Such work shall require a 48-hour advance notification and will not be scheduled outside normal working hours for City Utilities’ crews unless prior approval has been received. Contractor shall dig and prepare excavation with shoring and traffic control as necessary. Contractor shall install tapping fitting, valve and provide hoisting equipment for installation and removal of tapping machine. Contractor may tap newly installed HDPE mains that are not in service using an EF branch saddle and tapping with a hole saw when approved by Resident Engineer. All shavings and debris shall be removed from the main after tap is made.

3.17

RETIRED WATER LINES

- A. Other than minimum lengths as shown on the drawing and where retired water main conflicts with the installation of this projects' improvements, Contractor may leave retired water main in place. Contractor may elect to remove old main, in which case pipe shall become Contractor's to salvage. However, backfill, compact and restore all excavations performed in removing old pipe according to the Contract requirements, which may include backfilling with granular material under proposed or existing roadway areas and cleanup of established areas. No payment will be made to the Contractor for this pipe removal and excavation and restoration.
- B. Plug and seal ends of all retired water lines with caps or plugs.
- C. When necessary to complete installation of this project's improvements, remove retired water mains, services and meter pits, backfill and restore area per Contract requirements at no additional charge.
- D. Retire asbestos cement (AC) pipe per Missouri Department of Natural Resources (MoDNR) requirements and as specified within this Section.
- E. Contractor shall remove existing fire hydrants down to, and including, the shoe and return to City Utilities. Remaining piping shall be filled with a Froth Pack. Contractor shall also retire existing valve box below grade. Coordinate with CU Inspector for delivery instructions of salvaged hydrant material. Contractor shall fill and repair to existing grade.
- F. All other retired valves and fittings shall be retired below grade per the Construction Standards, unless noted for removal.

3.18

SERVICE RENEWALS AND TIE-OVERS

- A. Install new meter set and new meter tile per standards, retire existing service and install new customer service piping from the outlet of the meter tile to behind the property line to reconnect the customer's piping per applicable standards. Meters shall be installed as close as practical to the customer's property line or easement line.
- B. All plumbing work shall conform to all applicable code requirements.
- C. Coordinate with Inspector regarding the routing of the customer line and the scheduling of the work.
- D. Services shall be completely renewed main to meter and backside of service tied to customers piping as called for within this Specification unless specifically called out to remain and be tied over to the new main on the Drawings.

3.19

RETIREMENT OF EXISTING SERVICES AND METER SETTINGS

Where services are called to be retired, retire at the main by closing the curb stop valve and install locator marker ball. Where services are being retired as part of ongoing construction, install a section of one-inch pipe vertically over the corporation stop one foot above the top of the corporation stop to serve as a marker. When the main is also being retired physical retirement of the services at the main is not required. Remove meters from the existing setting and return to City Utilities. Remove rings and lids for reuse in relocated service installations or for return to City Utilities material yard. When retiring a meter tile, the elevation shall be adjusted to a position below grade backfill according to Section 02315 and restore surface per Section 02700 or Section 02900.

When service lines and meter sets not shown on the Drawings are encountered during the course of construction, notify the Inspector to determine whether service is to be replaced or abandoned.

3.20 REMOVAL OF DAMAGED PIPE

HDPE pipe found to have surface damage at a depth equal to or greater than 10% of the wall thickness, as determined by the Inspector, shall not be acceptable. Contractor shall cut out and replace with undamaged section of HDPE pipe, at the expense of the Contractor

Other piping materials found to have damage unacceptable to the Inspector, shall be cut out and replaced with undamaged pipe at the expense of the Contractor.

3.21 ASBESTOS CEMENT PIPE REPAIRS, DEMOLITION, AND DISPOSAL

Contractor is being made aware that work on asbestos cement (AC) pipe is governed by OSHA regulations and that compliance with OSHA regulations is the sole responsibility of the Contractor. Work on AC pipe shall only be performed by OSHA trained personnel overseen by a “competent person” as defined by OSHA. Contractor shall be or retain a Registered Asbestos Contractor with the Missouri Department of Natural Resources. Additionally, all work shall be in accordance with EPA’s *National Emission Standards for Hazardous Air Pollutants (NESHAP)*, EPA’s *Governmental Employee Worker Protection Rule*, and *Missouri DNR’s Air Asbestos Rule*.

- A. EXCAVATION: When excavating an AC water main, take precautions to prevent the backhoe teeth from scraping or gouging the pipe. Use a spotter to warn when the pipe is first exposed. Use heavy equipment to excavate laterally down to and around the pipe, and then complete the job by hand. This is especially important if the pipe is to be retired and removed.
- B. PIPE PREPARATION: AC pipe must be kept wet at all times while cutting, scraping, chipping, or otherwise abrading the pipe. Water mixed with a surfactant (soap, detergent or other agent, designed to reduce surface tension of the water) must be used to wet the pipe. A Hudson type sprayer shall be used to apply the solution. The solution shall be applied frequently to areas of the pipe being abraded.
- C. CUTTING: Asbestos-containing pipe shall *never* be cut with a high-speed mechanical saw. Pipe shall be severed with a hand-operated pipe cutter or uncoupled and removed in entire joint lengths.
- D. CORING (TAPPING): When tapping into an AC pipe do not use high-speed mechanical boring equipment. Minimize dust by using a hand-operated drill or auger. If the tapping hole is too large for a hand drill, use an electric drill specially equipped with a HEPA vacuum attachment. Treat all collected dust, crumbs, coupons, etc. as asbestos waste by collecting in and/or on plastic bags and sheeting.
- E. RETIREMENT: Unless otherwise indicated on the Drawings, all existing AC pipe shall be abandoned in place. “Abandoned in place” pertains only to those sections of pipe that have not been moved from their location of original installation. All abandoned-in-place AC pipe shall be made locatable per one of the approved methods specified in the Construction Standards.
- F. REMOVAL: Pipe sections that have been removed or disconnected from their installed position must be removed from the trench and properly disposed of. Pipe sections and fragments removed from the trench must be immediately packaged for disposal and moved to a secure location. This may entail placing directly into a lined roll-off container and/or double wrapping or bagging individual pieces of pipe and/or pipe fragments in 6-

mil plastic bags or sheeting. A locator marker ball shall be placed at all locations where asbestos pipe has been exposed. All cost for the proper disposal of AC pipe shall be borne by the Contractor.

- G. DECONTAMINATION: All tools and equipment used during the maintenance of the AC pipe shall be thoroughly cleaned with soap, water, and disposable towels. All materials such as towels used for cleaning, gloves, or plastic sheeting that becomes contaminated with asbestos containing material shall be packaged and disposed of properly.
- H. DISPOSAL: Contractor is responsible for ensuring all sections and pieces of AC pipe and materials that cannot be abandoned in place are properly packaged and disposed of at a licensed solid waste landfill approved by City Utilities. If desired, City Utilities will provide guidance to the Contractor on the landfill's waste approval process. However, costs for disposal are borne by the Contractor, unless otherwise indicated on the Drawings or in these Specifications. Contractor will document disposal by providing to City Utilities the waste manifest(s) signed and returned to the Contractor by the landfill representative.
- I. REPORTING: Contractor is responsible to report to City Utilities information necessary for reporting compliance to Missouri Department of Natural Resources. Contractor shall supply the name of the competent person who is performing any work on the pipe or any pipe removal, transport and disposal. The contractor shall provide the name and location of the disposal facility. This information shall be submitted to City Utilities Environmental Affairs at least 20 days prior to work on the pipe.

END OF SECTION

SECTION 02515

DISINFECTION AND TESTING

PART I GENERAL

1.01 This covers disinfection and testing of the water distribution system.

PART II MATERIALS AND EQUIPMENT

2.01 Contractor shall supply all necessary materials and equipment for the work described in Part III unless otherwise specified.

PART III EXECUTION

3.01 TESTING

A. PREVENTATIVE MEASURES DURING CONSTRUCTION

During construction, the interior as well as all sealing surfaces of pipe, fittings, and other accessories should be kept as clean as possible. Inspect the interior of all pipes prior to installation. If dirt enters the pipe, it should be removed, and the affected interior of the pipe swabbed with a 1%-5% chlorine solution. All openings in pipelines should be closed with watertight plugs whenever the trench is unattended. Plugs should be treated with a 1%-5% chlorine solution prior to being inserted into the mains to avoid contamination. Likewise, fittings such as tapping fittings, valves, leak clamps, etc. shall be swabbed or sprayed with a 1%-5% chlorine solution to prevent contamination. Sealing, lubricating, or gasket materials used in pipe installation should be stored and handled in a manner that avoids contamination and be suitable for use with potable water. During construction, standing water in the trench that has the potential to enter open pipe ends should be treated with calcium hypochlorite tablets not intended for use in swimming pools according to AWWA 651 to ensure contaminants are not introduced into the pipe.

B. PRELIMINARY FLUSHING OF MAINS

Before pressure testing and disinfection, the main should be completely filled with water from the low point to the high point when possible, to eliminate air pockets and then flushed to purge the line of dirt and debris. The initial fill should be done slowly in order to eliminate all air pockets. The flow rate should not exceed 1 ft/s. All air relief valves, hydrants, and other access points should be opened during initial fill in order to ensure all air has been expelled. Ineffective removal of dirt and debris from lines prior to disinfection often leads to failed bacterial tests, requiring repeated disinfection. Preliminary flushing should follow the initial slow fill and should be done to achieve a flow rate of at least 2.5 ft/sec to scour the main and remove all foreign material. The initial fill shall be performed by the Contractor with the Inspector present. Preliminary flushing shall be performed by City Utilities Water Operations. Times shall be recorded for calculation of the amount of water used.

The following table shows the required flow rate to obtain a velocity of 2.5 ft/sec in commonly used sizes of pipe.

Flow Rates for Filling & Flushing

	1.0 ft/s Fill Velocity	2.5ft/s Flushing Velocity
Pipe Size (inches)	Flowrate (gpm)	Flowrate (gpm)
2	10	25
4	39	98
6	88	220
8	157	391
12	352	881
16	626	1566
24	1409	3523
36	3171	7927
48	5637	14,093

C. HYDROSTATIC TESTING

The purpose of the hydrostatic test is both to test for the ability of the pipeline to withstand the applied pressure and to test for leakage. Hydrostatic tests shall be conducted in accordance with the following:

<u>Pipe Material</u>	<u>Criteria</u>
HDPE	AWWA C906, 651 & Manual M55; PPI Handbook of Polyethylene pipe 2 nd edition, ASTM F2164
PVC	AWWA C605, C900, & Manual M23
Ductile Iron	AWWA C600 & Manual M41

Contractor shall provide a liquid filled or digital gauge that has increments of 2 psi or less. The gauge shall be calibrated and accurate to within one percent. Contractor shall provide pressure gauge calibration logs upon request of the Inspector.

Pressure testing shall not begin until all concrete thrust blocks, collars and restraint have cured to achieve the desired compressive strength. After the pipe has been laid, the main shall be filled slowly from the low point to the high point when possible and all air purged from the line through available hydrants, blow offs, and air relief valves. Once all air has been removed close air reliefs and other valves. The maximum length of piping to be tested at once shall be 2500 feet unless approved by Resident Engineer. The main shall be tested at 150 psi gauged at the highest elevation of the water main under test or corrected for the elevation of the test gauge if not at the high point.

The following formula shall be used to correct for the elevation difference between the high point of the section being tested and the location of the testing pump and gauge:

$$\text{Test Pressure} = 150 \text{ (psi)} - \frac{[\text{high pt. elevation (ft.)} - \text{Test gauge elevation (ft.)}]}{2.31 \text{ (ft/psi)}}$$

If extreme terrain differences are encountered on the project the piping pressure test shall be done in segments to ensure that no segment is pressure tested more than 1.5 times the systems design pressure rating.

a) PROCEDURE FOR PVC AND DI WATER MAINS

Gradually pressurize the test section to 150 psi at the highest point of the test section and maintain that pressure for two (2) hours or for the duration called for by the Resident Engineer. Add and measure make-up water as required to

maintain test pressure. Clean potable water from an uncontaminated container shall be used for make-up water. Monitor and record the amount of make-up water utilized and document on the as-built drawing. Ensure that the amount of makeup water used to maintain the test pressure does not exceed the maximum allowable leakage in the applicable AWWA standards or as calculated for each pipe size in the test section based on length. Use the table below to calculate the allowable makeup water volume for standard 150 psi test. Any allowable leakage noted on the Drawing is calculated for the entire piping length for the project.

<u>Main Size</u>	<u>Maximum Allowable Make up Water PVC or DI Mains (gallons per hour per 1000 feet)</u>
8	.66
12	.99
16	1.32
24	1.99
30	2.48
36	2.98
48	3.97

$$\text{Maximum Allowable makeup water (gal/hr)} = \frac{(\text{length}) * (\text{diameter}) * \sqrt{(\text{test pressure})}}{148,000}$$

If the test indicates leakage greater than the maximum allowable rate, locate and repair the defect. Run tests again after correction is made until leakage is within the allowable rate. Furnish all necessary labor and equipment for testing.

b) PROCEDURE FOR HDPE WATER MAINS

The test procedure for HDPE consists of an initial expansion and a test phase. Gradually pressurize the test section to 150 psi at the highest point of the test section adding make-up water as required to maintain test pressure for up to four hours. The test section pressure may be stabilized, and the pipe expansion accomplished in less than the allotted four-hour period but a minimum of one hour shall be used for the expansion period in all cases. After the expansion period (1-4 hours) is completed, the pressure shall remain steady for an additional one hour at the test pressure. If leaks are discovered, depressurize the test section before repairing leaks. Correctly made fusion joints should not leak. Leaking joints shall be cut out and replaced and retested.

If the pressure test is not completed due to leakage or other events, the test section should be depressurized for at least eight hours before retesting begins. Furnish all necessary labor and equipment for testing.

D. TRACER WIRE TESTING

Test tracer wire to verify a continuous signal on the wire. Contractor shall dig up and repair tracer wire where the signal isn't continuous.

E. HDPE DESTRUCTIVE TESTING

City Utilities reserves the right to perform destructive testing on up to 10% of the HDPE fusion joints installed by the Contractor on the project. Contractor is responsible for cutting out the joint identified by the Inspector or Resident Engineer and replacing the

section removed with a new section of fused HDPE pipe. The pipe joint shall be tested using a side-bend test. If the pipe joint fails, the Contractor shall be responsible for additional testing.

3.02

DISINFECTION

- A. Disinfection of the water main and appurtenances shall be done in accordance with AWWA C-651 latest revision and this specification under the supervision of the City Utilities Inspector and Water Technician. After the pressure test, the Inspector will make arrangements with Water Operations to disinfect the installed lines. Contractor shall give City Utilities notice 48 hours in advance of the need for disinfection.
- B. Perform disinfection operations after hydrostatic pressure tests have been completed. Do not perform disinfection until all line segments are ready for disinfecting, unless otherwise directed. Use no water from a new main for any purpose until disinfection is completed and accepted. City Utilities shall place out of service rings on all valves and fire hydrants until the main has been disinfected and ready for service.
- C. Install and remove sample assemblies per construction drawings and standards to allow the main to be disinfected and sampled as directed by the Inspector. Points to sample the main will be required every 600 feet and at the end of all branch mains at a minimum. Service taps may be utilized as sample assembly points when appropriately located. Sample assembly to be shut off and the riser pipe cut and capped as close as possible to the main when retiring sample assembly. Provide a blow-off at the end of the main being disinfected to provide a means of flushing. Blow-off and sample assembly details are shown on the Standard Drawings.
- D. Pretreatment of valves, sleeves, tees, and other fittings that present areas that can hold sediment or debris is encouraged. They should be treated with a 1%-5% chlorine solution prior to or during assembly. Tie in sections of piping or short segments of piping that do not lend themselves to standard disinfection shall be swabbed with a 1%-5% chlorine solution to provide disinfection.
- E. All water mains shall be disinfected by City Utilities using the continuous feed method in accordance with AWWA C651 except as noted otherwise. The slug method prescribed in AWWA C651 may also be used with prior approval from the Resident Engineer when placing a main back in service in a quicker time frame is necessary. The continuous feed method that should be followed is described as follows: Sodium Hypochlorite in a liquid form shall be injected to perform the disinfection of the line. A chlorine solution may also be mixed using granular calcium hypochlorite to be injected into the water lines. The chlorine injected shall be no lower than 1% available chlorine (10,000ppm) and no higher than 10% available chlorine (100,000ppm). Chlorine shall be injected at the beginning of the main being tested through a sample assembly located within four feet from the main feed valve supplying water. The feed valve supplying water shall be opened just enough to produce a very low flow (not a heavy stream) through the main exiting at the blow-off or hydrant at the end of the line. The chlorine solution shall then be constantly injected by pumping while the concentrations of chlorine are tested to ensure a consistent concentration throughout the main is achieved. Sampling of the chlorine concentration during injection should start at the sample assembly located closest to the injection point then moving away from the injection point toward other assemblies and to the end of the main. Injection is complete once testing at all sample assembly locations (at least every 600 ft. and at the end of all branch mains) have indicated that chlorine concentrations are at least 25 ppm. This shall be verified once injection has ceased. When stopping the injection process the feed valve supplying water shall be shut off first followed by the chlorine feed. The blow-off or hydrant at the end of the line should be closed as soon as the injection has stopped. The chlorine concentrations shall be no lower than 10 ppm 24

hours following the injection. The results of this testing shall be provided to the Resident Engineer. The highly chlorinated water used for disinfection shall not remain in the water main longer than ninety-six hours.

City Utilities may use high-test chlorine tablets to disinfect new water mains less than 50' in length. The tablets can be secured to the top of each section of pipe with an approved food grade adhesive during main installation to supply the chlorine for disinfection. Use a minimum of one tablet per inch of pipe diameter per joint of pipe, up to 12" diameter pipe, based on the rate of ¼ ounce tablets with 65% available chlorine. Do not use the tablet method with polyethylene (HDPE) pipe or if trench water or foreign material enters the main. The use of 90% available chlorine tablets is not allowed. Store chlorine tablets in a sealed, opaque container until immediately before use.

- F. Following disinfection, City Utilities Water Technician will flush and chemically de-chlorinate as needed the treated water from the line at all extremities until water in main has comparable chlorine residuals to surrounding system mains. The water in the main will then be sampled by the Water Technician 24 hours later at points at least every 600 feet and at the end of all branch mains and examined for contamination per AWWA standards. Water will be sampled by the Water Technician a second time after 15 minutes. During the sampling process water will not be flushed from the main except what is necessary to flush the sample assembly piping in order to retain the same water in the installed water pipe for the full sampling process. The feed valve may be opened slightly during the process, if necessary, to maintain pressure to obtain samples. After two consecutive sets of acceptable water quality samples, the main will then be approved and final tie-ins authorized to be made to the distribution system. Consideration shall be given by the Contractor for runoff water during the flushing process. Results of all water quality tests shall be provided to the Resident Engineer.
- G. City Utilities will flush and sample a new main up to two times or four total quality sample tests. If water quality tests are still failing, the above disinfection process will be repeated. If the main still does not pass the water quality tests City Utilities may require the Contractor to pig the water main and continue to repeat the disinfection process until the main passes the quality tests. The Contractor will provide all labor, equipment, and all materials necessary to pig the main. This process shall continue until two consecutive water quality tests yield good results. Pigs used shall provide a general sweeping and swabbing of the line. They shall be foam (1-2lb/cubic foot density) with urethane coated nose cone wrapping and urethane rear sealing. Pigs should be able to pass through reduction of up to 60% to 65% of cross-sectional area of nominal pipe. Pigs shall be able to traverse standard piping configurations such as 90° elbows, tees, crosses, wyes, gate valves, and ball valves. Contractor shall be responsible for all pigging activities including but not limited to breaking down of the line to insert and remove the pig, tracking of the pig, removal of stuck pig, disposal of the pig and material removed from the line.

3.03

CONTINUITY OF SERVICE

Prior to closing any valves, notify all affected customers 24 hours in advance and state how long the service will be curtailed. Cause no customer to be without service for more than eight hours. Schedule all tie-ins and other operations affecting customer service only as approved by the Inspector. Carefully plan such operations in advance, verify materials and conditions, and work continuously until all customers are in service. Some off-hour work and overtime labor may be required to avoid causing unnecessary hardship for business, schools, etc. Contractor shall bid accordingly.

END OF SECTION

SECTION 02550

MECHANICAL – NATURAL GAS PIPING

PART I GENERAL

1.01 DESCRIPTION: Includes, but is not limited to, installation, retirement and/or relocation of natural gas mains and services, including pipe, valves and fittings.

1.02 RELATED WORK DESCRIBED ELSEWHERE: Section 02220, Demolition and Clearing, Section 02315 Excavation and Backfilling, Section 02410 Tunneling.

1.03 PRODUCT HANDLING

- A. Use all means necessary to protect the material before, during and after installation.
 - 1. Handle pipe with padded forklifts, wide non-abrasive slings, padded clamps or padded pipe hooks. Pipe must be secured so that it cannot fall while being handled. Conventional chains, chain hooks and non-padded forklifts are expressly forbidden.
 - 2. Use wooden skids or padding for material storage. All steel pipe and fitting shall be stored off the ground on wooden pallets or skids.
 - 3. Contractor is responsible for all dents, gouges, coating defects and/or dimensional variations.
- B. In the event of damage, immediately make all repairs and replacements to the approval of the Inspector.

PART II PRODUCTS & EQUIPMENT

2.01 Unless otherwise indicated on project Specifications, plastic gas pipe, along with plastic valves and fittings, shall be (polyethylene) PE 2708 material, and steel gas pipe shall be API5L Grade B or X42 with fusion bonded epoxy coating.

2.02 HEAT FUSION EQUIPMENT

- A. All heat fusion equipment to be used within the contract shall be maintained in accordance with the manufacturer's recommended practices or with written procedures that have been proven by test and experience to produce acceptable joints.
- B. Contractor shall submit the Natural Gas Pipe Fusion affidavit in Attachment A prior to fusing any pipe under the contract, with appropriate supporting documentation for any written procedures that differ from the manufacturer's recommended practices.

PART III EXECUTION

3.01 INSTALLATION – GENERAL

Contractor shall install natural gas mains and services to make all required interconnections and at required grades with all fittings and valves at the required locations.

3.02 INSTALLATION METHODS

- A. Install natural gas pipe by trenching as set forth in Section 02315, Excavation and Backfilling; by tunneling, as set forth in Section 02410, Tunneling; or by Insertion.

- B. The minimum allowable depth for a service line to be inserted on private property shall be 18” for insertion through plastic service lines and 12” for insertion through steel service lines. The minimum depth on Right of Way shall be 18”.

3.03

PIPE CLEANING

- A. Prevent foreign material from entering the pipe while it is being installed. If the pipe laying crew cannot put the pipe into the trench without getting foreign material in the pipe, then a heavy, tightly woven canvas bag of suitable size shall be placed over each end and left there until the connection is to be made to the adjacent pipe. During laying operations, no debris, tools, clothing or other materials shall be placed in the pipe.
- B. When pipe laying is not in progress, close the open ends of pipe with a watertight plug or other approved means. This provision shall apply during meal breaks as well as overnight. If water is in the trench, the seal shall remain in place until the trench is pumped completely dry. Pipe shall not be laid in water or when trench conditions are unsuitable.

3.04

NATURAL GAS MAIN DEHYDRATION

- A. Contractor shall be responsible for installing natural gas piping in a manner that does not allow water to enter the pipe. If the Inspector determines there is water in any natural gas piping two inches or larger in diameter, the Contractor shall be responsible for pigging that pipe in a manner approved by the Resident Engineer. The pipe shall be pigged repeatedly by the Contractor until the Resident Engineer has determined that the pipe is sufficiently dehydrated.
- B. Pipeline pigs shall be Girard Poly Pig YBS-B, KRG or equal. Contractor shall supply all pigs. Inspector shall inspect pig after passage through pipe to determine if that pig may be reused.
- C. Contractor shall be responsible for blocking passage of pig into pipes which do not need to be pigged. If pig passes into a pipe which does not need to be pigged, or if pig becomes stuck in the pipe, the Contractor shall retrieve the pig at his own expense, including but not limited to any excavation, pipe repair and landscape or pavement restoration.
- D. If there is water in any natural gas piping, the Contractor shall be responsible for dehydration of the line as directed by the Inspector and to the Inspector’s satisfaction.

3.05

STEEL PIPE JOINING METHODS

- A. City Utilities shall perform all joining of steel pipes and fittings, unless otherwise noted in the Bid Documents. When the Contractor is required to join steel pipe and fittings it shall be done by the shielded metal arc welding process and the following requirements shall apply:

- B. WELDING PROCEDURES

- 1. All welding, including welder qualification testing, shall be done following City Utilities written welding procedure specification (which complies with API 1104), or Contractor may submit for approval his own written welding procedure and procedure qualification records with his bid documents. Resident Engineer shall determine acceptability of submitted procedures based on API 1104 in advance of welder qualification testing. If Contractor has submitted his

own procedure, he must have his procedure qualified per API 1104 as in Item B.2. below.

2. All welding shall be done by competent welders who shall have been tested by an AWS certified welding inspector approved by City Utilities. The welding test shall comply with the requirements of the Missouri Public Service Commission Regulations and API 1104 and shall be administered by a welding inspector certified by the American Welding Society to have complied with the requirements of Section 6.1 of AWS QC1-88, "Standard for AWS Certification of Welding Inspectors." A list of companies with certified welding inspectors approved by City Utilities will be made available to the Contractor upon request.

The Contractor shall arrange and pay for all welder and procedure qualification testing. This expense is coincident with the installation of steel gas main and shall not be considered grounds for additional charge to City Utilities. Welders shall perform a 12-inch multiple qualification test in accordance with API 1104 and have the results documented on a City Utilities approved form.

Contractor may choose to use an AWS inspector or testing company other than those listed by City Utilities but must obtain approval in advance from Resident Engineer.

3. No natural gas materials will be issued to the Contractor until the welding procedure and the minimum number of welders required by that procedure have been tested and then approved by Resident Engineer. City Utilities will provide pipe for weld tests from the storeroom at 1402 N. Newton. Contractor shall be responsible for cutting pipe nipples to length and picking up the pipe for the tests.
4. Welders must have natural gas or petroleum pipeline welding experience or have been previously qualified by City Utilities or MANGO.
5. Contractor shall furnish all oxygen, acetylene, fuel, welding rod, welding machines, beveling machines, weld clamps, all tools and other material required for welder qualification testing and welding work. Welders using defective or deficient equipment or lacking these necessary tools will not be tested.
6. If welding is interrupted during weather conditions which may cause uneven or accelerated cooling of the weld, the joint shall be wrapped with insulating material and the weld joint shall be preheated when welding resumes. Weld must be preheated, if required by the Welding Procedure Specification.
7. Short "pup" joints must be a minimum of one pipe diameter, or 24" whichever is longer.

C. WELDING CODES

All welding must comply with the requirements of the following codes and standards:

1. Missouri Public Service Commission Pipeline Safety Regulations, 4 CSR 240-40.030, Section (5) "Welding of Steel in Pipelines."
2. Transportation of Natural and Other Gas by Pipeline: Minimum Federal Safety Standards, Part 192, Subpart E and Appendix C.

3. API Standard 1104, Standard for Welding Pipelines and Related Facilities, latest edition.
4. ASME/ANSI B31.8. – Code for Pressure Piping.
5. Any other applicable local, state or federal regulations or codes.

D. WELDING EQUIPMENT

1. All machines and equipment used in connection with the welding work must be kept in good mechanical condition.
2. Non-arcing clamps are required for all pipe welding.

E. PREPARATION FOR WELDING

1. FIELD BEVELING OF PIPE ENDS: All steel pipe which is field-cut must have the ends properly beveled per API Standard 1104, latest edition, before welding. Bevel the pipe ends by machine tool or machine oxygen cutting. The beveled ends should be smooth and uniform. Dimensions shall be in accordance with the approved welding procedure. Mitered joints are not acceptable.
2. 90° welding elbows cut to make elbows of lower angle must be re-beveled as specified above. Elbows thus produced must have an inside arc length (crotch) of at least 1-inch.
3. Welders must shield from weld splatter the fusion-bond epoxy coating of pipe beyond the 2-inch cutback and alignment clamp by wrapping coated area with a leather protector.
4. Contractor shall provide protection for welders while working during cold, rainy or stormy weather, or other adverse weather conditions (blowing sand and dust, etc.) to assure good quality welds. Welding will not be done when the Inspector judges that weather conditions are severe enough to impair quality of the welds. Multiple welders may be required if the size of the pipe and the weather conditions dictate.
5. Prior to alignment, the beveled ends of each joint of pipe shall be thoroughly cleaned of paint, rust, mill scale, dirt or other matter.
6. Longitudinal seams of successive lengths of pipe shall be offset by a minimum 25 percent of the pipe diameter.

F. REPAIR OF DEFECTIVE WELDS

1. If non-destructive or visual inspection indicates a weld is defective, the Contractor shall cut a cylinder of pipe from the pipeline containing the defective weld and replace it with good pipe, welded properly, at no additional charge.
2. The Contractor may also elect to repair the weld in accordance with requirements of Section 7.0 of API Standard 1104, except all cracked welds shall be cut out and replaced as in F.1. above.

G. ARC BURNS

1. Contractor shall take necessary measures to avoid arcing between ground leads of the welding machines and the pipe or fittings. Striking the arc on the pipe or fittings at any point other than the welding groove shall not be permitted.
2. All arc burns on the pipe shall be removed by cutting out that portion of pipe as a cylinder and replacing with good pipe at no additional charge to City Utilities.
3. Arc burns in fittings, valves and tie-in welds may be repaired by grinding with prior authorization by the Inspector. The area repaired by grinding shall be checked for complete removal of the arc burn and metallurgical notch. The remaining wall thickness must then be verified.

3.06 FIELD BENDING OF STEEL PIPE

- A. The minimum radius of curvature for all diameters of steel pipe shall be 1553 times the outside diameter of the pipe.
- B. Field bending of steel pipe below the minimum radius of curvature shall not be allowed unless otherwise specified in the bid documents.

3.07 REMOVAL OF DAMAGED PIPE

- A. Natural gas pipe found to have surface damage at a depth equal to or greater than 10% of the wall thickness, as determined by the Inspector, shall not be acceptable. Contractor shall cut out and replace with undamaged section of pipe, at the expense of the Contractor.
- B. Other natural gas fittings or materials found to have damage unacceptable to the Inspector, shall be cut out and replaced at the expense of the Contractor.

3.08 PROCEDURES FOR COATING JOINTS AND FITTINGS AND REPAIRING ALL AREAS OF COATING DAMAGE ON STEEL PIPE

- A. Pipe shall be jeepped and holidays repaired prior to lowering into trench. Clean the outside of the area to be protected of all foreign substances such as dirt, scale or rust. Remove oil or grease by a solvent. Coat the area per Construction Standards or as otherwise indicated on the plans. Allow coated areas to air dry completely before being backfilled.
- B. All pipe coatings shall be applied in accordance with manufacturer's recommended procedure, specifically including the recommended use of primers.
- C. Field applied polymer concrete shall be used to coat joints on polymer concrete coated steel pipe for uncased bores. Coating shall be allowed to cure completely prior to insertion through the bore hole. Coating may not be applied to welds that have been made within the previous fifteen hours.

3.09 LOWERING-IN

- A. Steel pipeline shall be lowered into the ditch following field coating of weld joints and after pipe and coating have been inspected and approved by Inspector for lowering in. Adequacy of equipment used for lowering-in shall be subject to the approval of the Inspector.
- B. During lowering-in, pipe shall be handled by use of rubber tire rollers or lowering-in belts of proper design to prevent damage to the coating.

- C. Lowering-in must be done gradually and uniformly so as to allow even distribution of the total weight of the pipe to avoid undue stress on the pipe and to prevent damage to the pipe coating. Do not drop or subject the pipe to impact.
- D. Remove all debris, skids, welding rods, etc. from the bottom of trench before lowering the pipe.
- E. After lowering-in, the pipe coating shall be inspected for possible damage. If the pipe coating has been damaged, the pipe shall be raised again, inspected by jeeping, and the coating repaired.

3.10

PLASTIC PIPE JOINING METHODS:

- A. Polyethylene pipe shall be joined by heat fusion, electrofusion or approved mechanical couplings as specified in the Construction Standards.
- B. All joints shall be made by competent joiners who shall have been tested and approved in advance by City Utilities, and who have properly maintained this qualification. The test shall comply with the requirements of the Missouri Public Service Commission Regulations. The test shall include destructive test of joints of each type to be made on the project.

C. HEAT FUSION

- 1. Contractor shall make all fusions in accordance with ASTM F2620.
- 2. Contractor shall provide all tools and an acceptable butt fusion machine capable of fusing all sizes of piping for the project. All tools shall be electrically heated only. Fuel-fired tools shall not be acceptable. Only tools specifically designed for the joining of polyethylene gas pipe shall be used. All tools shall be kept clean.
- 3. Data loggers shall be used when performing butt fusions with a hydraulic machine. City Utilities Inspector will provide the data logger. Hydraulic butt fusion equipment shall be McElroy or pre-approved equal. When equipment other than McElroy is proposed, the Contractor will be required to supply an equivalent data logger or other approved means of capturing fusion data and providing the fusion data to City Utilities Inspector.

D. ELECTROFUSION

- 1. Contractor shall provide all tools and an acceptable electrofusion machine capable of fusing all sizes of piping for the project.
- 2. The pipe shall be prepared using an approved scraper designed for use with medium density polyethylene piping. Paint-type scrapers will not be allowed.

E. MECHANICAL

- 1. Contractor shall provide all tools capable of installing mechanical fittings in the sizes depicted in the Construction Standards.
- 2. The fittings shall be installed per the manufacturer's specifications.

E. DESTRUCTIVE TESTING

1. City Utilities reserves the right to perform destructive testing on up to 10% of the joints installed by the Contractor on the project. Contractor is responsible for cutting out the joint identified by the Inspector or Resident Engineer and replacing the section removed with a new section of pipe.
2. The pipe joint shall be tested using industry standards tests. If the pipe joint fails, the Contractor shall be responsible for additional testing.

3.11 VALVE AND FITTING INSTALLATION

- A. Contractor shall set valves and fittings and join to pipe as shown on the Drawings and Construction Standards.
- B. Contractor shall install a valve box for every valve. The valve box shall not transmit shock or stress to the valve and shall be centered and plumb over the operating nut of the valve. The box cover shall be flush with the surface of the finished grade or as directed by the Inspector.

3.12 BENDING OF POLYETHYLENE (PLASTIC) PIPE

- A. Install fittings at all locations as specified in the Drawings.
- B. At locations where fittings are not specifically called for, plastic pipe may be bent to route the line as required; however, bends which would produce excessive stress on the pipe shall not be allowed. The bending radius shall adhere to the manufacturer's recommendations and the Natural Gas Construction Standards. Where bend radius will not conform to the Construction Standards and manufacturer's recommendations, an appropriate fitting (elbow) shall be installed as necessary.

3.13 CUTTING OF POLYETHYLENE (PLASTIC) PIPE

- A. Cut pipe square and remove all burrs and cuttings prior to joining.
- B. Pipe may be cut with a hacksaw or carpenter's saw, or a specifically designed plastic pipe cutter may be used.
- C. Standard metal pipe wheel-cutters are not acceptable.

3.14 SQUEEZE-OFF OF POLYETHYLENE (PLASTIC) PIPE

- A. Where available, City Utilities personnel shall utilize valves to control the flow of natural gas in plastic pipes. When valve isolation is not possible, City Utilities personnel shall squeeze off plastic mains, and Contractor shall squeeze off service lines.
- B. Contractor shall squeeze-off pipe per the Construction Standards.

3.15 LOCATOR WIRE

- A. Contractor shall install locator wire with all plastic main and service piping per the Construction Standards. Plastic service lines that do not have existing locator wire shall be replaced with a new service line with locator wire.
- B. Contractor shall connect wire to existing locator wire where present. Do not connect wire to any existing steel gas mains or services. Connect wire utilizing a direct bury splice kit.

3.16

CATHODIC PROTECTION, ANODES AND TEST STATIONS

- A. Contractor shall replace damaged anodes and test stations and install new magnesium anodes and test stations at points designated on the Drawings per City Utilities Standards. The Inspector shall be present when test stations are installed.
- B. Contractor shall connect test wires and anode wires to the natural gas line by thermite welding (cadwelding) in accordance with City Utilities Construction Standards. Maximum charge to be utilized in the thermite welding procedure shall be 15 grams. Any procedure which is deemed harmful to the natural gas line will not be permitted. Fast quenching with water to achieve a quick cool down is not permitted.
- C. Cutting of the steel portion of “Anodeless” risers is not allowed.
- D. Contractor shall coat the thermite welded area per City Utilities Construction Standards.

3.17

PRESSURE TESTING

A. NEW INSTALLATIONS

- 1. Contractor shall subject all new piping installed to an air or nitrogen pressure test unless otherwise specified in the Contract Documents. Contractor shall provide all material and equipment required for pressure testing.
 - 2. Contractor shall provide a liquid filled or digital gauge that has increments of 2 psi or less. The gauge shall be calibrated and accurate to within one percent. Contractor shall provide pressure gauge calibration logs upon request of the Inspector.
 - 3. Contractor shall test all mains to be operated at 60 psig or less at 90 psig for a minimum of one hour or as directed on the Drawings or standards.
 - 4. Contractor shall test all services at 90 psig for a minimum of fifteen minutes. Long or larger services may require additional time, per Construction Standards.
 - 5. Inspector shall determine acceptability of all pressure tests.
- B. FINAL TIE-INS: Soap test all final connections which cannot be air-pressure tested after the tie-in section is pressurized with natural gas.
 - C. Inspector may also test any of the work after it is pressurized with natural gas leak detecting equipment.
 - D. LEAKAGE: If any of the above described tests on new installations result in leakage, the defective pipe, joint or fitting shall be located and repaired, and tests shall be made again after the correction is made.

3.18

PRESSURE CONTROL WORK:

A. TAPPING AND STOPPING OF STEEL MAINS

- 1. All steel mains shall be tapped or stopped using the appropriate pressure control fitting.

2. Contractor shall furnish all equipment and labor required to place equipment and materials in advance of and as needed by City Utilities Pressure Control personnel, including digging, hoisting, bolting and welding. City Utilities shall be responsible for welding on all pressure control fittings unless indicated otherwise in the Bid Documents.
3. City Utilities Pressure Control personnel shall provide labor and equipment to make the tap or stoppling on 12" diameter and smaller piping with pressure 150 psig or less. When tapping or stoppling work is to be performed on mains larger than 12" or on mains operating above 150 psig, Contractor shall secure the services of an approved company to perform the operations. A list of approved companies is available from Resident Engineer.

B. SQUEEZE-OFF OF POLYETHYLENE (PLASTIC) MAINS AND SERVICES

Contractor shall provide all necessary tools and labor to squeeze-off new and existing plastic mains and service, utilizing procedures as prescribed in Section 3.14.

C. Operations of Main Line Natural Gas Valves:

City Utilities shall operate all main line natural gas valves as required in coordination with Contractor's work.

D. PURGING

1. All mains shall be purged of air after a satisfactory pressure test is completed.
2. Contractor shall install all necessary fittings for purging.
3. City Utilities shall provide all necessary labor for purging all mains.

E. NOTICE REQUIRED

1. Contractor shall coordinate the sequencing of all required Pressure Control work with the Inspector.
2. A 48-hour advance notice is required for any Pressure Control operation.
3. All tapping and stoppling operations shall be scheduled to commence in the morning hours so that work can be completed during the normal City Utilities work day. Tapping and stoppling operations will not begin after 12:00 noon.

3.19 CONTINUITY OF SERVICE

- A. Contractor shall follow direction of the Inspector to maintain a maximum degree of continuous service to City Utilities' customers.
- B. Service shall not be interrupted overnight unless special arrangements are made with the involved customers by Contractor.
- C. Once Contractor has begun a specific procedure which requires an interruption of service, Inspector shall have the authority to require the Contractor to work continuously until said service is restored at no additional charge.
- D. Contractor shall notify customers 24 hours in advance of service interruptions.

3.20 RESTORATION OF SERVICE

City Utilities will be responsible for relighting of all natural gas services. Contractor shall coordinate this work and give immediate notice to the Inspector whenever a service is ready to be relighted.

3.21 RETIRED NATURAL GAS MAIN AND SERVICES

- A. Other than minimum lengths as shown on the drawing and where retired natural gas main conflicts with the installation of this projects' improvements, Contractor may leave retired natural gas main in place. All retired natural gas mains shall have the ends plugged or sealed with caps or foam sealant, as approved by the Inspector.
- B. When necessary to complete installation of this project's improvements, or otherwise at Contractor's discretion, Contractor shall remove and dispose of retired natural gas mains and services. The affected area shall be backfilled and restored per Contract requirements and meet all jurisdictional agency requirements. No additional charge shall be made by Contractor for any work associated with removal of pipe.
- C. All other retired valves and fittings shall be retired below grade per the Construction Standards, unless noted for removal.

3.22 PIPING WITH ASBESTOS COATING REPAIRS, DEMOLITION, AND DISPOSAL

Contractor is being made aware that work on piping with asbestos material within the coating of the pipe is governed by OSHA regulations and that compliance with OSHA regulations is the sole responsibility of the Contractor. Work on pipe with asbestos coating shall only be performed by OSHA trained personnel overseen by a "competent person" as defined by OSHA. Contractor shall be or retain a Registered Asbestos Contractor with the Missouri Department of Natural Resources. Additionally, all work shall be in accordance with EPA's *National Emission Standards for Hazardous Air Pollutants (NESHAP)*, EPA's *Governmental Employee Worker Protection Rule*, and *Missouri DNR's Air Asbestos Rule*.

- A. EXCAVATION: When excavating a natural gas pipe with asbestos coating, take precautions to prevent the backhoe teeth from scraping or gouging the pipe. Use a spotter to warn when the pipe is first exposed. Use heavy equipment to excavate laterally down to and around the pipe, then complete the job by hand. This is especially important if the pipe is to be retired and removed.
- B. PIPE PREPARATION: Piping with asbestos coatings must be kept wet at all times while cutting, scraping, chipping, or otherwise abrading the pipe coating. Water mixed with a surfactant (soap, detergent or other agent, designed to reduce surface tension of the water) must be used to wet the pipe. A Hudson type sprayer shall be used to apply the solution. The solution shall be applied frequently to areas of the pipe coating being removed.
- C. CUTTING: Piping with asbestos coating shall *never* be cut using a high-speed mechanical saw without first removing the coating.
- D. CORING: When tapping or coring pipe with asbestos containing coating, remove all coating from the affected area prior to installing any tapping fittings on piping. A hammer or similar tool shall be used to break away large chunks of the coating from the pipe. A putty knife or similar tool shall be used to remove any remaining layers of the

asphaltic coating. Plastic sheeting shall be placed beneath or beside the pipe to collect all coating as it is removed. Treat all collected coating, dust, crumbs as asbestos waste. Once coating removal is complete, ensure that all pieces of coating are retained on the plastic sheeting, placed in plastic bags and properly disposed.

- E. RETIREMENT: Unless otherwise indicated on the Drawings, all existing piping with asbestos containing coating shall be abandoned in place. "Abandon in place" pertains only to those sections that have not been moved from their location of original installation. All abandoned-in-place AC pipe shall be made locatable per one of the approved methods specified in the Construction Standards.
- F. REMOVAL: Pipe sections that have been removed or disconnected from their installed position must be removed from the trench and properly disposed of. Pipe sections and fragments of coating removed from the trench must be immediately packaged for disposal and moved to a secure location. This may entail placing directly into a lined roll-off containing and/or double wrapping or bagging individual pieces of pipe and/or pipe fragments and/or coating fragments in 6-mil plastic bags or sheeting. All cost for the proper disposal of pipe and/or coatings which is removed without direction and written authorization of the Resident Engineer, shall be borne by the Contractor.
- G. DECONTAMINATION: All tools and equipment used during the maintenance of piping with asbestos coating shall be thoroughly cleaned with soap, water, and disposable towels. All materials such as towels used for cleaning, gloves, or plastic sheeting that becomes contaminated with asbestos containing material shall be packaged and disposed of properly.
- H. DISPOSAL: Contractor is responsible for ensuring all sections and pieces of piping with asbestos containing coating that cannot be abandoned in place are properly packaged and disposed of at a licensed solid waste landfill approved by City Utilities. This also includes any coating debris collected. Prevent damage to the coating when transporting pipe sections. Frayed coating edges must be wrapped in plastic or secured with duct tape. The pipe length should be limited to 20 feet, or as dictated by the disposal Contractor. Do not transport pipe with loose coating unless it is adequately wrapped in plastic. If desired, City Utilities will provide guidance to the Contractor on the landfill's waste approval process. However, costs for disposal are borne by the Contractor, unless otherwise indicated on the Drawings or in these Specifications. Contractor will document disposal by providing to City Utilities the waste manifest(s) signed and returned to the Contractor by the landfill representative.
- I. REPORTING: Contractor is responsible to report to City Utilities information necessary for reporting compliance to Missouri Department of Natural Resources. Contractor shall supply the name of the competent person who is performing any work on the pipe or any pipe removal, transport and disposal. The contractor shall provide the name and location of the disposal facility. This information shall be submitted to City Utilities Environmental Affairs at least 20 days prior to work on the pipe.

END OF SECTION

SECTION 02580

UNDERGROUND ELECTRIC CONDUIT AND EQUIPMENT

PART I GENERAL

1.01 DESCRIPTION: Includes, but is not limited to, primary and secondary risers, trench, conduit, transformer pads, equipment pads, primary junction cabinets, secondary pedestals, secondary cabinets, secondary vaults, conduit elbows and streetlights.

1.02 RELATED WORK DESCRIBED ELSEWHERE:

Section 02220 – Demolition and Clearing

Section 02315 – Excavation and Backfilling

Section 02410 – Tunneling

Section 02700 – Paving and Surfacing

Section 02900 – Landscaping

Section 03300 – Concrete

PART II PRODUCTS

1.01 Materials will be approved by City Utilities. Contact City Utilities Transmission and Distribution Engineering for a list of approved materials.

- A. Contractor to supply all electrical materials per “Developer Installed Work” on drawing.
- B. City Utilities to supply: junction cabinets, plastic transformer pads, secondary service pedestals, PVC to Galvanized adapters, stand-off brackets for risers and street light bases. Refer to section 01640.

PART III EXECUTION

3.01 INSTALLATION OF PVC CONDUIT PIPE:

- A. The Contractor shall handle all PVC conduit with care to prevent damage. PVC conduits shall be placed in trench as shown in the Electric Construction Standards Drawings, and in locations as shown on plans issued by City Utilities. The joining of conduit pieces shall be accordance with manufacturer’s recommendations and will be done only with joint cement and primer approved by City Utilities. Any conduit that is split, broken, crushed, or flattened shall not be installed.
- B. The ends of all conduit runs shall be sealed using PVC conduit plugs and clearly labeled to indicate where they are going. The ends of all conduit runs shall have a conduit/cable marker attached to designate location.
- C. Plastic warning tape shall be installed in trench between 6-inches and 12-inches below finished grade.
- D. The PVC conduit shall be installed in such a manner as to insure an unobstructed raceway for pulling conductor in the conduit at some future time. During conduit installation contractor to install a pull-string by blowing a “Mouse” in conduit from point

of beginning to point of termination. “Mouse” size to match conduit size. Install a continuous run of binder twine with a breaking strength of at least 150 pounds in each conduit, extend a minimum of four feet of twine past each end. Do not blow the string into energized equipment.

- E. Contractor shall prevent foreign material from entering the conduit while it is being placed in the line. Allow no debris, tools, clothing or other materials in the pipe.
- F. When conduit laying is not in progress, open ends of the pipe shall be closed with a plug or cap to prevent entry of foreign materials.

3.03 PERMISSIBLE DEFLECTION:

- A. Deflections shall not exceed the pipe manufacturer’s specifications.

3.04 CONDUIT CUTTING:

- A. All conduit cutting shall be done in strict accordance with the pipe manufacturer’s specifications.

3.05 INSTALLATION OF ELBOWS-GALVANIZED AND PVC:

- A. Install per Engineering drawings.
- B. Verify depth of trench necessary to correctly install ells at proper depth in relation to final grade at junction enclosures, transformers and secondary pedestals.
- C. Templates provided by City Utilities shall be used to arrange ells in the proper footprint. Bundling or taping of ells together in one bunch is not acceptable.
- D. The tops of ells in a transformer should be set flush with the top of the pad.
- E. The tops of ells in primary junction cabinets and primary fuse cabinets should be set at 18” below final grade. The tops of ells in secondary pedestals should be set at 12” below final grade.

3.06 GROUND RODS:

- A. Contractor shall provide and install ground rods.

3.07 INSTALLATION OF ELECTRIC EQUIPMENT:

- A. The Contractor shall handle all electric equipment with care to prevent damage. Equipment shall be installed as shown in the Electric Developer Construction Standard Drawings (<https://www.cityutilities.net/business/construction/>) and in accordance with Manufacturer’s Recommendations.



- B. The Inspector shall be notified as to the start of equipment installation so as to ensure proper installation of equipment.

END OF SECTION

SECTION 02700

PAVING AND SURFACING

PART I GENERAL

- 1.01 DESCRIPTION: Includes, but is not limited to, pavement replacement in streets, driveways and sidewalks. Pavement repairs required due to potholing for utilities are to be performed per this Specification and are considered inclusive in the per foot pipe prices established in the contract.
- 1.02 RELATED WORK SPECIFIED ELSEWHERE: Excavation and Backfilling; Section 02315.

PART II MATERIALS AND EQUIPMENT

- 2.01 Meet appropriate jurisdictional agency paving standards.

PART III EXECUTION

3.01 GENERAL PAVING REPLACEMENT

- A. All paving replacements and associated costs are the sole responsibility of the Contractor. Paving must be restored according to the appropriate jurisdictional agency's requirements and be performed to their satisfaction.
- B. When trench excavations are made on private property, parking lots or driveways, backfill immediately with compacted granular material according to excavation Specifications to restore access. Install a smooth final repair of like material within 30 days of the trench backfill.
- C. Install a smooth temporary patch across streets the same day as the trench is backfilled. Final repair shall be completed within 30 days of the trench being backfilled.

3.02 PAVING AND SURFACING

Existing sidewalks, sidewalk ramps or driveways shall be removed to the nearest contraction or isolation joint, unless otherwise approved by the appropriate jurisdictional agency. The curb and gutter section in front of a driveway (radius point to radius point) shall be saw cut full depth and removed before the driveway is constructed. Any curb and gutter damaged by Contractor's operation outside the radius points during this removal and/or reconstruction shall also be removed and replaced accordingly at the Contractor's expense. Any damage to the existing street shall be the responsibility of the Contractor.

3.3 REGULATORY COMPLIANCE

Comply with all applicable jurisdictional requirements.

END OF SECTION

SECTION 02900

LANDSCAPING

PART I GENERAL

1.01 DESCRIPTION: Includes, but is not limited to, the items listed below.

- A. Performing preliminary cleanup.
- B. Planting bushes, trees or plants.
- C. Applying topsoil to disturbed areas on right-of-way and easements.
- D. Hydraulic seeding of disturbed areas.
- E. Cultivation and drilling of disturbed pasture or cropland areas.
- F. Re-seeding during specified seeding windows.
- G. All disturbed areas to be restored to as good as or better than original condition.

1.02 RELATED WORK SPECIFIED ELSEWHERE

- A. Excavation and Backfilling; Section 02315.
- B. Demolition and Clearing; Section 02220.

PART II MATERIALS AND EQUIPMENT

2.01 TOPSOIL

- A. Fertile, friable soil of loamy character, free of sub-soil, stumps, refuse and other foreign material.
- B. Normal amount of natural humus and reasonably free of roots, hard dirt, heavy or stiff clay, coarse sand, noxious weeds, noxious weed seeds, sticks, brush and other litter.
- C. Obtained from well-drained, arable land and be of an even texture.
- D. Not infested with nematodes or with any other noxious animal life or toxic substances.
- E. Sandy loam of low fertility, even though mixed with leaf mold, manure or other fertilizers is not acceptable.

2.02 GRASS SEED

- A. Clean, dry new crop seed.
- B. Provide grass seed for established areas in a blend as specified below, unless directed otherwise by the landowner or Inspector:
 - 1. 75% by weight of a three-way blend (equal parts) of turf fescues, consisting of any three of the following varieties: Olympic, Falcon, Bonanza, Rebel, Hound Dog, Astro 2000, Eldorado, Wrangler, FineLawn One, Anthem or Apache.

2. 15% by weight of Perennial Rye, consisting of one or more of the following varieties: Affinity, Derby, Regal, Manhattan or Chateau.
 3. 10% by weight of Bluegrass, consisting of either Kentucky Bluegrass, Park Bluegrass or both.
 4. Purity 98%.
 5. Germination 85%.
- C. Complies with standards of the Official Seed Analysis of North America.
- D. Recommended for full sun exposure in Springfield, Missouri.
- E. Seed shall be free from Johnson Grass, Canadian Thistle or field bind weed seed.

2.03 FERTILIZER

Provide a mixture containing 13 pounds each of soluble nitrogen, phosphate and potash per 100 pounds.

2.04 MULCH FOR HYDRAULICALLY SEEDED AREAS

Provide a mixture of 50% recycled slick paper mulch and 50% ground corrugated paper mulch by weight. The recycled slick paper mulch shall be produced from printers' slick paper containing wood cellulose and kaolin clay. Newsprint is not allowed. The slick paper mulch shall have a maximum moisture content of 8% by weight and shall have a pH of 4.5 to 6.5. The corrugated paper mulch shall have a moisture capacity of 700 grams water per 100 grams dry mulch minimum, a dry moisture content of 12% maximum, and a pH of 5.0 to 8.0. All mulch materials must be free of any germination or growth-inhibiting substances, green in color, and have the property of being evenly dispersed and suspended when agitated in water.

Clean wheat straw shall be applied over the hydraulic mulch.

2.05 SOD

Sod shall be placed at the locations indicated on the plans. At locations where sod is not indicated, seeding and/or landscaping shall be placed, as indicated herein. In the event the CU inspector designates an area is required to be sodded that has not been indicated on the plans to be sodded, the Contractor shall be compensated for sodding per the alternate unit bid item indicated.

The first row of sod shall be laid in a straight line, with subsequent rows placed parallel to and tightly against each other. Lateral joints shall be staggered to promote more uniform growth and strength. Care shall be exercised to avoid stretching or overlapping the sod and to ensure that all joints are butted tight in order to prevent voids which would cause air drying of the roots.

During periods of higher than optimal temperature and after all unevenness in the soil surface has been corrected, the soil shall be lightly moistened immediately prior to laying the sod. The Contractor shall water sod immediately after transplanting to prevent excessive drying. As sodding is completed in any one section, the entire area shall be rolled. It shall then be watered to a sufficient depth to thoroughly wet the underside of the new sod pad and the soil immediately below the sod. Staking of sod on slopes will be optional; however, the Contractor shall be solely responsible for replacing sod displaced by erosion or other causes.

Upon meeting the requirements previously indicated for placement of sod, the Contractor shall utilize the Long-Term Care Agreement in Attachment B and obtain acceptance and signature from the respective property owner. A copy of the signed form shall be submitted to City Utilities.

PART III EXECUTION

3.01 PRELIMINARY CLEANUP

Clear disturbed areas, including those disturbed by trenching, storing of dirt, pipe laying, pipe storage, movement of equipment and other work of all rubbish, brush, rock, trash and excess dirt in a timely manner as soon as the ditch is backfilled, depending upon existing conditions and level of public concern. This may be required as often as daily. Rake surface as necessary to remove all above items, including all rock measuring two inches or more in its greatest dimension. In pasture and cropland areas, remove all above items in a timely fashion. Tractor-drawn equipment, including rock rakes and steel roller drum are allowed.

Project Construction Phasing: Each project, section, and/or area shall be worked in manageable segments, to minimize the duration of neighborhood inconvenience. The project shall be constructed per the phasing plan indicated on the drawings. In the absence of a phasing plan, these segments should be discussed with, and agreed upon with the CU Inspector at the onset of the Project and will end at normal breaking points in the flow of work, such as tie-ins and blow-offs when possible.”

3.02 PLANTING

Contractor shall replace individual trees, plants and shrubs as necessary or as directed by the Inspector. Plant in accordance with "Planting Trees and Shrubs" by the University of Missouri - Columbia Extension Division (Publication No. 6850). Replacement trees, plants and shrubs shall be nursery grown and of the same type, strain, size and value as those removed. Plant replacement trees, plants and shrubs as soon as possible after installation of mains, with due consideration given to optimal times of the year to plant the given species.

3.03 APPLICATION OF TOPSOIL

Established lawn and parkway areas

After preliminary cleanup has been performed, apply topsoil meeting the requirements of PART II, MATERIALS AND EQUIPMENT to a minimum depth of four inches to disturbed areas. Pulverize topsoil and grade to match existing terrain. Rake surface smooth for sod or to provide a good seedbed for hydraulic seeding as specified below.

3.04 SEEDING

Perform initial seeding as soon as practical after preliminary cleanup and application of topsoil. Restore all disturbed areas, except for pasture and cropland, by hydraulic seeding. Seeding windows are specified as follows: Perform autumn seeding between August 15 and October 15, and spring seeding between March 15 and May 15. If initial seeding is performed within either of the specified seeding windows, the only additional work required of the Contractor shall be warranty work. When seeding outside a normal seeding window quick germinating seed shall be used such as winter wheat or perennial rye to establish ground cover. Contractor may be required to provide and install erosion control blankets to protect these areas. Re-seeding during the next earliest seeding window shall be considered part of the work if initial seeding falls outside either of the specified seeding windows. The Inspector will determine if re-seeding is required.

- A. HYDRAULIC SEEDING: Mix seed, fertilizer and mulch with water and constantly agitate so that a uniform mixture can be applied hydraulically to the specified areas. Do not add the

seed to the water more than four hours before application. Calculate ratios of seed, fertilizer, mulch and water so that seed will be applied at the rate of twelve pounds minimum per 1000 square feet of area, fertilizer will be applied at the rate of eight pounds minimum per 1000 square feet of area, and mulch will be applied at the rate of 1000 pounds minimum dry weight per acre. Wet application rate of the mixture shall be 2000 pounds per acre minimum. Blow wheat straw mulch onto the hydraulic mulch within one hour of application of the hydraulic mulch.

B. RESTORATION OF DISTURBED PASTURE AND CROPLAND AREAS

1. SEED BED PREPARATION: Tillage - prepare a seed bed by use of tillage operations that leaves a seed bed free of weeds. Leave the vegetative material destroyed by such operations on the surface. Several diskings or harrowings over same area may be required to provide a satisfactory seedbed.
2. SEEDING METHOD: DRILLING: Plant the recommended seed with a grass drill equipped with double coulter furrow openers with depth bands and press wheels. Seed should be planted 1/4" to 1/2" deep. Cultipacking is required following seeding.
3. FERTILIZER REQUIREMENTS: Apply fertilizer at the rate 8 pounds minimum per 1,000 square feet.
4. SEEDING RATES AND MIXTURE: Apply seed grass(es) at the rate (pure live seed or bulk seed per acre) of 30 lb/acre, or as recommended by the seed supplier.
5. Where permanent seeding must be delayed due to seasonal seeding or climate conditions, quick germinating seed such as winter wheat or perennial rye will be applied. Contractor may be required to provide erosion control blanket to provide protection to the disturbed areas until vegetation can be established. Subsequently drill temporary cover with no-till methods to establish permanent crop cover.

- C. RESTORATION OF SLOPES: When areas with slopes 3:1 or greater are restored a biodegradable erosion control blanket shall be installed over the seedbed to protect the slope (Propex CS2 or approved equal). Contractor shall supply the fabric and staples and install per manufacturer's recommendations.

END OF SECTION

SECTION 03200

CONCRETE REINFORCEMENT

PART I GENERAL

- 1.01 Furnish all labor, materials and equipment necessary to complete the work as specified in this Section.
- 1.02 Comply with the provisions of the Concrete Reinforcing Steel Institutes "Manual of Standard Practice" unless more stringent requirements are shown.

PART II MATERIALS AND EQUIPMENT

- 2.01 Reinforcing bars will be sized according to the plans and will be ASTM A615, Grade 60, deformed bars.
- 2.02 Steel wire will be plain, cold-drawn and will conform to ASTM A82.
- 2.03 Use bolsters, chairs, spacers or other devices for spacing, supporting and fastening the reinforcing bars in place.

PART III EXECUTION

- 3.01 The reinforcement will be fabricated to the shapes and dimensions shown and placed where indicated. Lap splices will be made in conformance with ACI Standard 318.
- 3.02 The reinforcement will be free from all substances that would reduce or destroy the bond. After a substantial delay, steel left exposed will be inspected and cleaned.
- 3.03 Reinforcement detailing and placement, including concrete protection for steel reinforcement, unless otherwise indicated, will conform to ACI Standards 318 and 315 and will match reinforcement as shown on the Drawings.
- 3.04 Wire mesh reinforcement will be continuous between crack-control joints in slabs-on-grade. Laps will be at least one full mesh, staggered in both directions, and secured with wire or standard clips. Wire mesh will extend to within 2 inches of joints but not through joints.
- 3.05 Supports will be installed and intersections of reinforcement securely tied with steel wire to limit displacement to the tolerances permitted by ACI Standard 315. The number, type and spacing of supports will conform to ACI Standard 315, unless otherwise indicated.
- 3.06 Reinforcement for slabs-on-grade will be supported on precast concrete blocks. Size and spacing of blocks will be as required to provide firm support and the clearance specified or indicated. Set wire ties so ends are directed into concrete, not toward exposed concrete surfaces.
- 3.07 Reinforcement and other fixed metal items shall not be continuous through expansion or control joints.

END OF SECTION

SECTION 03300

CONCRETE

PART I GENERAL

1.01 DESCRIPTION

This Section covers all cast-in-place concrete, including reinforcing steel, forms, finishing and other appurtenant work for thrust blocks, thrust collars and other items shown on the Drawings. Also see Section 03200, Concrete Reinforcement.

1.02 RELATED WORK DESCRIBED ELSEWHERE

Water Piping, Section 02510.

PART II MATERIALS AND EQUIPMENT

2.01 MATERIALS

Cement	ASTM C150, Type I or ASTM C715, Type IA.
Fine Aggregate	Clean natural sand, ASTM C33.
Coarse Aggregate	Crushed rock, washed gravel or other inert granular material conforming to ASTM C33.
Water	Potable
Reinforcing Steel Bars	ASTM A615, Grade 60

2.02 PRELIMINARY REVIEW

Submit the source and quality of concrete materials and the concrete mix along with test data proposed for the work to the Inspector for review, before any concrete is placed.

2.03 SLUMP

Keep concrete slump as low as possible consistent with proper handling and thorough compaction. Unless otherwise authorized by the Inspector, slump shall not exceed 4 inches except for flowable fill. Add no water to mix after the slump test without approval by Resident Engineer.

2.04 STRENGTH

The minimum acceptable compressive strengths as determined by ASTM C39 shall be as follows:

<u>Age</u>	<u>Minimum Strength</u>
7 days	2500 psi
28 days	3750 psi

Very high early strength concrete shall achieve a 2500 psi compressive strength within 3 hours. Contractor shall submit mix design for high early strength concrete to Inspector for review prior to placement along with compressive strength documentation.

Flowable fill compressive strength shall be demonstrated by failure to deform or crush under foot traffic.

2.05 STORAGE OF MATERIALS

Store cement in suitable moisture proof enclosures. Do not use cement which has become caked or lumpy. Store aggregates so that segregation and the inclusion of foreign materials are prevented. Do not use the bottom 6 inches of aggregate piles in contact with the ground.

Reinforcing steel shall be carefully handled and shall be stored on supports which will keep the steel from contact with the ground.

2.06 REINFORCEMENTS

Reinforcements shall be accurately formed and shall be free from loose rust, scale and contaminants which reduce bond.

PART III EXECUTION

3.01 BATCHING AND MIXING

Furnish concrete from an acceptable ready-mix concrete supplier or mix at the site. Concrete shall at a minimum conform to ASTM C94.

3.02 PLACING CONCRETE

Thrust blocks and thrust collars shall be placed between solid, undisturbed earth and the fitting or piping to be anchored. Thrust blocks shall be so placed that the pipe and joints will be accessible for repair and installed per Construction Standards. The minimum compressive strength for the concrete shall be achieved prior to relying on the concrete for any thrust restraint. The use of very high early strength concrete is permissible for installations where time constraints exist.

When the Drawings call for flowable fill or Contractor wishes to utilize flowable fill in lieu of compacted backfill, no additional payment will be made. Contractor shall make requests to utilize flowable fill to the Resident Engineer. Flowable fill mix and placement shall conform to Specifications of local jurisdictional agency or at a minimum the Missouri Standards Specifications for Highway Construction latest edition.

3.03 FINISHING

No surface treatment will be required for buried concrete not forming an integral part of a structure except that required to obtain the surface elevations or contours and surfaces free of laitance.

3.04 INSPECTION

No concrete shall be covered until installation has been approved by City Utilities.

3.05 REPAIR OF DEFECTIVE WORK

In the event that concrete installation is found to be sub-standard, the Contractor shall be required to remove and replace installation with proper materials and execution.

END OF SECTION

ATTACHMENT A

REQUIRED FORMS & AFFIDAVITS

- SAMPLE MATERIAL SUBMITTAL FORM
- NATURAL GAS PIPE FUSION AFFIDAVIT

Material Submittal Prepared for:
<<Contractor’s Name>>

Project Name:
<<Subdivision/Project Name>>

Submittal Prepared by:
<<Material Supplier Name>>
<<Material Supplier Address>>

I certify that the material brands included in this submittal comply with City Utilities of Springfield, MO’s “Gas & Water Inventory Acceptable Brands and Items Specs” as listed on City Utilities’ website as of the date below, unless otherwise noted.

Material Supplier Signature

Date

City Utilities - Reviewed by:

Signature

Date

Water Materials

Approved Water Materials

Quantity	Stock #	Description	Brand
100'	2505897	PIPE, POLY., 1 IN., IPS, STICK, SDR11, HDPE, 20 FT	United Poly Systems
1000'	2501352	PIPE, POLYETHYLENE, 1 IN., IPS, 500 FT. SDR 11, HDPE	Polypipe (500') Duraline (500')

- *Instructions*
 - *The items listed above are for example only. Include all columns shown above. Add lines as necessary to list all approved water material included in the project.*
 - *For non-approved material:*
 - *Add the section shown below. Include all columns shown. Add lines as necessary to list all non-approved water being proposed for approval.*
 - *BE SURE to include specifications or cut sheets with this submittal.*

Proposed NON-APPROVED Water Material Brands*

Quantity	Stock #	Description	Brand
X	2504397	PIPE, PVC, 24 IN, WATER, PUSH-ON, C905, 20' LENGTH	ABC Brand
1000'	2504261	PIPE, PVC, 16 IN, WATER, PUSH-ON, C905, 20' LENGTH	DEF Brand (200') XYZ Brand (800')

* See attached specification sheets.

- *Provide a similar list of all approved and non-approved natural gas material.*

STATE OF MISSOURI)
) SS.
COUNTY OF GREENE)

NATURAL GAS PIPE FUSION AFFIDAVIT

Before me, the undersigned authority, personally appeared _____ who,
being by me duly sworn, deposed as follows: (Name)

- 1. I am of sound mind, capable of making this affidavit, and personally acquainted with the facts herein stated.
- 2. I am the _____ of _____ ;
(Title) (Name of Company)
- 3. All requirements of Section 02550 of City Utilities Technical Specifications have been fully satisfied with regard to this company’s work on _____ ;
(Name of Project)
- 4. I have reviewed and am familiar with City Utilities requirements for verifying that all equipment used for heat fusion of polyethylene pipe has been maintained in accordance with PHMSA part 192.756; Based on my knowledge of these requirements per the federal statute, I have validated that full and accurate maintenance has been performed per the manufacturer’s guidelines or validated written procedure attached for all heat fusion equipment used on this project.
- 5. The matters stated herein are true to the best of my information, knowledge and belief. I acknowledge that the falsification of any information set out above may subject me to criminal prosecution pursuant to 570.090, 575.040, 575.050, 575.060, RSMo.

Affiant

In witness whereof, I have hereunto subscribed my name and affixed my official seal this _____ day of _____, 201__.

Notary Public

My commission expires:

ATTACHMENT B

OTHER FORMS

- CROSS BORE VERIFICATION FORM

STATE OF MISSOURI)
) SS.
COUNTY OF GREENE)

AFFIDAVIT

Before me, the undersigned authority, personally appeared _____ who, being by me duly sworn, deposed as follows:
(Name)

1. I am of sound mind, capable of making this affidavit, and personally acquainted with the facts herein stated.

2. I am the _____ of _____ ;
(Title) (Name of Company)

3. All requirements of 319.037 RSMo and Section 02410 of City Utilities Technical Specifications have been fully satisfied with regard to this company's work on _____ ;
(Name of Project)

4. I have reviewed and am familiar with City Utilities requirements for verifying that cross bores are prevented; Based on my knowledge of these requirements and state statute, I have completed full and accurate records on the City Utilities Cross Bore Verification Form clearly indicating the visual or camera inspection results of all sewer locations crossed by tunneling during this project.

5. The matters stated herein are true to the best of my information, knowledge and belief. I acknowledge that the falsification of any information set out above may subject me to criminal prosecution pursuant to 570.090, 575.040, 575.050, 575.060, RSMo.

Affiant

In witness whereof, I have hereunto subscribed my name and affixed my official seal this _____ day of _____, 201__.

Notary Public

My commission expires: