



RELATED STANDARDS
 PR3-*
 PR3V-*

MATERIAL LIST

QTY.	DESCRIPTION	STOCK NO.	QTY.	DESCRIPTION	STOCK NO.
1	CONDUIT, RIGID 4" GALVANIZED 5' LENGTH	139247		PR-4C (WITHOUT POLE) CONDUIT, RIGID 4" GALVANIZED 2.5' LENGTH	138275
2	ADAPTER, 4" PVC TO GALVANIZED	119888			
3	ELBOW, CONDUIT 4" RIGID, 90°, 36" RADIUS	120104	4		
5	COUPLING, CONDUIT 4" GALVANIZED	120023	2		
6	PLUG, CONDUIT 4" PVC	119969			
7	TAPE, WARNING "BURIED ELECTRIC CABLE"	139571			
			4		
			8	BRACKET, CONDUIT STANDOFF 12" T-SLOT	108033
			9	STRAP, "U" 4" CONDUIT	120320

- GENERAL NOTES**
- INSTALL CONTINUOUS RUN BINDER TWINE (MINIMUM TENSILE STRENGTH OF 140 LBS) IN CONDUIT.
 - TURN CONDUIT UP SO THAT 2.5' OR 10' PIECE IS PLUMB.
 - BACKFILL PER TRENCH STANDARD.

**ELECTRIC CONSTRUCTION STANDARD
 CITY UTILITIES OF SPRINGFIELD MO.**

DRAWN BY:
GKH

REV BY:
JKH

FILE:
PR-4

APPROVED:
7-30-08

REVISED:
2/26/09

SHEET
OF
1 OF 1

STD. NO.
PR-4*

**PRIMARY RISER
 3-PHASE
 CONDUIT INSTALLATION**