



TOP VIEW WITH COVER REMOVED SHOWING THE BELOW GRADE PEDESTAL AND CONDUIT ELBOWS (TYPICAL).

RELATED STANDARDS  
SP1-\*

MATERIAL LIST

QTY.	DESCRIPTION	STOCK NO.	QTY.	DESCRIPTION	STOCK NO.
1	PEDESTAL, SMALL SECONDARY GROUND LEVEL	121265			
2	COVER, DOMED FOR GRADE LEVEL SERVICE VAULT	121346			
3	1" DIRTY BASESTONE (APPROXIMATELY 1/3 YARD)	N/A			
4	MARKER, BURIED CABLE/PIPE	109300			
5	ROD, GROUND (5/8" x 8') COPPERWELD	102341			

**GENERAL NOTES**

- INSTALL A MINIMUM 5 FEET OF CONDUIT ON END OF EACH SERVICE ELBOW. NUMBER AND SIZE OF SERVICE CONDUIT(S) PER CUSTOMER PLANS.
- BACKFILL WITH 1" DIRTY BASESTONE FROM BOTTOM OF TRENCH.
- TRANSITION, IF NECESSARY, AT ONE INCH PER FOOT.
- INSTALL PVC PLUG IN EACH OPEN CONDUIT END.
- CONDUIT ELBOWS CALLED OUT SEPARATELY. NOTE: USE TWO ELBOWS PER SERVICE FOR LARGER HOUSES/SERVICES (I.E. 400A).

**ELECTRIC CONSTRUCTION STANDARD  
CITY UTILITIES OF SPRINGFIELD MO.**

DRAWN BY:  
G.GUEVARA

REV BY:  
JKH

FILE:  
SP-2C

APPROVED:  
8-13-08

REVISED:  
7-24-08

SHEET  
OF  
1 OF 1

STD. NO.  
**SP-2C**

SMALL  
SECONDARY PEDESTAL  
2" CONDUIT  
INSTALLATION