



MATERIAL LIST

QTY.	DESCRIPTION	STOCK NO.	QTY.	DESCRIPTION	STOCK NO.
FURNISHED AND INSTALLED BY CUSTOMER			FURNISHED + INSTALLED BY CITY UTILITIES		
1	METER PEDESTAL FOR 4-TERMINAL METER (FREE STANDING, RAIN TIGHT ENCLOSURE WITH BUILT IN MAIN SERVICE DISCONNECT)		5	4-TERMINAL METER	
2	METER BASE FOR 4-TERMINAL METER - \triangle (RAIN TIGHT ENCLOSURE)		6	METER SEAL	
3	SUPPORT STRUCTURE - \triangle				
4	MAIN SERVICE DISCONNECT - \triangle (RAIN TIGHT ENCLOSURE)				

\triangle GENERAL NOTES		ELECTRIC SERVICE STANDARD CITY UTILITIES OF SPRINGFIELD MO.			
1. SEE CONSTRUCTION DRAWING FOR TRANSFORMER STANDARD BEING USED FOR THIS PROJECT. 2. METER TO BE LOCATED NO CLOSER THAN 3' OR MORE THAN 100' FROM TRANSFORMER. 3. METER BASE SUPPORT MUST BE STEEL. 4. MINIMUM METER HEIGHT IS 30", MAXIMUM METER HEIGHT IS 48". 5. SEPARATE METER BASE AND SERVICE DISCONNECT OR COMBINATION METER BASE/ MAIN DISCONNECT UNIT IS ACCEPTABLE.		DRAWN BY: CK		SERVICE UNDERGROUND CUSTOMER METER AT TRANSFORMER	
		REV BY: K.DENTON			
		FILE: SU-M-PED			
		APPROVED: 10/29/14	REVISED: 03/19/18	SHEET OF 1 OF 1	STD. NO. SU-M-PED